

# Eastern Renewable Generation Integration Study





Aaron Townsend, Ph.D.

Solar Power International

Las Vegas, Nevada

October 21, 2014

# Eastern Renewable Generation Integration Study



# Answering Critical Questions


*Critical questions:*

- How might power system operations be impacted by wind and solar power generation?
- Could the operational impacts differ based on policy decisions about regional versus national deployment strategies?
- How can different operational practices mitigate the effects of variability and uncertainty?

# Study Limitations

- **We lack:**
  - Bilateral power purchase and other contractual agreement data
  - Detailed operational constraints and/or complete unit-specific data in the generation models
  - Capability to simultaneously model different dispatch intervals in different balancing authority areas
- **Uncertainties:**
  - Future cooperation and/or sub-hourly dispatch across the interconnection
  - The amount and location of variable generation
  - Transmission system additions
  - Generation additions and retirements
  - Gas and coal prices

# The Eastern Interconnection







- Generating capacity: 700 GW
- Generating units: 7,500
- Load: 3,000 TWh
- Population: 240 million people
- 70% of US Load
- Transmission length: 459,000 miles
- Nodes: 60,000
- Transmission lines: 50,000

# Approach




# 2026 Study Scenarios




# Modeling Software

- **PLEXOS**

- Unit commitment and economic dispatch
- Nodal DC power flow
- Day-ahead (hourly)
- Real-time (5-minute)
- Mixed-integer



# Eastern Wind Data Set




## About the data

- Simulated power data
- Sites: 1,326
- Years: 2004–2006
- Time: 10-minute resolution
- Capacity: 580 GW
- Mesoscale model
- 2-km resolution

**Where to get it:** [http://www.nrel.gov/electricity/transmission/eastern\\_wind\\_methodology.html](http://www.nrel.gov/electricity/transmission/eastern_wind_methodology.html)

**Where it has been used:** PJM Renewable Generation Integration Study, SPP Wind Integration Study

# Solar Integration Data Set







## About the data

- Simulated power data
- Sites: 4,089
- Years: 2006
- Time: 5-minute resolution
- Capacity: 174 GW
- Multiple forecasts

Where to get it: [http://www.nrel.gov/electricity/transmission/solar\\_integration\\_methodology.html](http://www.nrel.gov/electricity/transmission/solar_integration_methodology.html)

Where its been used: Minnesota Renewable Integration and Transmission Study, FPL Solar Integration Study

# Sub-Hourly Load Data for 2026




# High Performance Computing


- A decision at time  $t$  is not dependent on the state of the system at previous time intervals, given a delay of  $n$  time periods.



Photo by Steven Hammond, NREL



# Simulation Time Comparison



# Simulations




# 2026 Study Year Setup

---

- Day-ahead plus real-time (DA+RT) operational sequence
- Hourly commitment schedules for non-quick-start generators fixed in DA
- 5-minute dispatch in RT
- Regulation and contingency reserves in both DA and RT

# Preliminary Results: DA and RT Dispatch



# Mitigation Goals

---

- Minimize production costs
- Minimize emissions
- Minimize reserves violations
- Minimize RT unplanned startups

# Mitigation Option: Intra-Day Unit Commitment

- **Why?**
  - Take advantage of better short-term forecasts to recommit medium-startup time units such as NGCCs
  - Actively discussed in industry
  - Other studies either did not include it, or assumed it as part of the base case.
  - Isolates impacts
- **Approach**
  - Add a third operational step between DA and RT that commits combined cycle units.
  - 4 hour is the appropriate time period because the typical startup times needed for CCs is ~4 hours.

# Mitigation Option: Flex Reserves

---

- **Why?**
  - Ensure ramping capacity is available to address variability and uncertainty
  - Actively discussed in industry
  - Other studies either did not include it, or assumed it as part of the base case
  - Isolates impacts
- **Approach**
  - Add a third spinning reserve product in the DA but not the RT
  - Consistent with WWSIS-2 base case

# Mitigation Option: Combined

---

- **Why?**
  - Evaluate aggregate impact of mitigation options
  - Do the strategies reduce the effectiveness of each other?
- **Approach**
  - Use both intra-day unit commitment and flex reserve options

# Timeline

---

- Running simulations now
- Technical Review Committee meetings in December and March
- Final report available summer 2015

# Get Involved

---

- **Learn more:**  
[http://www.nrel.gov/electricity/transmission/eastern\\_renewable.html](http://www.nrel.gov/electricity/transmission/eastern_renewable.html)
- **Get data:**  
[http://www.nrel.gov/electricity/transmission/data\\_resources.html](http://www.nrel.gov/electricity/transmission/data_resources.html)
- **Final report: summer 2015**
- **Contact:**  
[aaron.townsend@nrel.gov](mailto:aaron.townsend@nrel.gov)

This work was supported by the U.S. Department of Energy under Contract No. DE-AC36-08-GO28308 with the National Renewable Energy Laboratory.