



AUGUST 21-23, 2018 • CLEVELAND, OHIO

# Liquid in the Rack: Liquid Cooling Your Data Center

NREL ESIF Data Center  
Otto Van Geet, PE – NREL

NREL/PR-7A40-72046

# NREL's Dual Computing Mission

- Provide HPC and related systems expertise to advance NREL's mission, and push the leading edge for data center sustainability
- Demonstrate leadership in liquid cooling, waste heat capture, and re-use
- Holistic “chips-to-bricks” approaches to data center efficiency
- Showcase data center at NREL's Energy Systems Integration Facility (ESIF)

## **Critical Topics Include:**

- Liquid cooling and energy efficiency
- Water efficiency

# Planning for a New Data Center

- Started planning for new data center in 2006
- Based on HPC industry/technology trends, committed to direct liquid cooling
- **Holistic approach**: integrate racks into the data center, data center into the facility, the facility into the NREL campus
- Capture and use data center waste heat: office and lab space (now) and export to campus (future)
- Incorporate high-power density racks—more than 60 kW per rack
- Implement liquid cooling at the rack, no mechanical chillers
- Use chilled beam for office/lab space heating. Low-grade waste heat use.
- Considered two critical temperatures:
  - Information technology (IT) cooling supply—could produce 24°C (75°F) on hottest day of the year, ASHRAE “W2” class
  - IT return water—required 35°C (95°F) to heat the facility on the coldest day of the year

***Build the World's Most Energy Efficient Data Center***

# NREL Data Center

## Showcase Facility

- ESIF 182,000 ft.<sup>2</sup> research facility
- 10,000 ft.<sup>2</sup> data center
- 10-MW at full buildout
- LEED Platinum Facility, **PUE ≤ 1.06**
- NO mechanical cooling (*eliminates expensive and inefficient chillers*)



*Utilize the bytes and the BTUs!*

## Data Center Features

- Direct, component-level liquid cooling, 24°C (75°F) cooling water supply
- 35-40°C (95-104°F) return water (waste heat) is captured and used to heat offices and lab space
- Pumps more efficient than fans
- High-voltage, 480-VAC power distribution directly to high power density 60- to 80-kW compute racks

## Compared to a Typical Data Center


- Lower CapEx—costs less to build
- Lower OpEx—efficiencies save

*Integrated “Chips-to-Bricks”  
Approach*


# Metrics

$$PUE = \frac{\text{“Facility energy”} + \text{“IT energy”}}{\text{“IT energy”}}$$

$$ERE = \frac{\text{“Facility energy”} + \text{“IT energy”} - \text{“Reuse energy”}}{\text{“IT energy”}}$$



Assume ~20MW HPC system & \$1M per MW year utility cost.



# Metrics


$$WUE = \frac{\text{“Annual Site Water Usage”}}{\text{“IT energy”}}$$

the units of WUE are liters/kWh

$$WUE_{SOURCE} = \frac{\text{“Annual Site Water Usage”} + \text{“Annual Source Energy Water Usage”}}{\text{“IT energy”}}$$

$$WUE_{SOURCE} = \frac{\text{“Annual Site Water Usage”}}{\text{“IT energy”}} + [EWIF \times PUE]$$

where EWIF is energy water intensity factor



# Air-Cooled to Liquid-Cooled Racks

Traditional **air-cooled** allow for rack power densities of 1kW-5kW




Require **liquid-cooled** when rack power densities in 5–80kW range, have several options





# Liquid-Cooled Server Options


**Peregrine HPC Tray**





**Cold Plates**




# Fanless Liquid-Cooled Server Options




**Fixed Cold Plate**



**Direct Immersion**



# Data Center Water Distribution




To/From 4th Floor  
Mechanical Room



# Liquid Cooling—Considerations

- Liquid cooling essential at high-power density
- Compatible metals and water chemistry is crucial
- Cooling distribution units (CDUs)
  - Efficient heat exchangers to separate facility and server liquids
  - Flow control to manage heat return
  - System filtration (with bypass) to ensure quality
- Redundancy in hydronic system (pumps, heat exchangers)
- Plan for hierarchy of systems
  - Cooling in series rather than parallel
  - Most sensitive systems get coolest liquid
- At least 95% of rack heat load captured directly to liquid

# Basic Hybrid System Concept



# Improved WUE—Thermosyphon



# ESIF Data Center Efficiency Dashboard



## ESIF HIGH PERFORMANCE COMPUTING DATA CENTER

As of Tue Aug 7 10:27:29 MDT 2018

Provided values in °F and GPM


OUTDOOR

Air Temperature 78.5 °F  
Relative Humidity 44.2 %

**PUE**  
1.044 =  $\left( \frac{10.33 + 18.27 + 6.15 + 5.83 + 931.14}{931.14} \right)$

**ERE**  
0.972 =  $\left( \frac{10.33 + 18.27 + 6.15 + 5.83 + 931.14 - 66.60}{931.14} \right)$

Values in kW



**Campus Hot Water HEX**

Out	83.9	88.1	In
Flow	74.8	134.3	Flow
In	78.8	80.8	Out
Heat Transfer (kW)		55.8    -74.8	

**Energy Recovery Water HEX**

Out	88.1	87.8	In
Flow	70.1	376.3	Flow
In	81.6	86.6	Out
Heat Transfer (kW)		66.6    -66.0	


**Fan Walls**

	South	North
Input Water	64.6	64.0
Output Water	72.5	71.1
Coil Flow	33.6	40.0
Coil Pump Power (kW)	0.1	0.2

	South	North
Air In Temp.	78.5	78.7
Air Out Temp.	67.6	67.6
Fan Power (kW)	2.1	2.1
Heat Energy Captured (kW)	38.9	41.7

**Where is Data Center Waste Energy Going?**

ESIF Building Heat	66.6 kW
Outdoors via Thermosyphon	97.7 kW
Outdoors via Cooling Towers	121.5 kW
Campus Building Heat	55.8 kW



# Data Center Metrics


## First year of TSC operation (9/1/2016–8/31/2017)

Hourly average IT Load  
= 888 kW

PUE = 1.034


ERE = 0.929

Annual Heat Rejection



WUE = 0.7 liters/kWh

(with only cooling towers, WUE = 1.42 liters/kWh)



$WUE_{SOURCE} = 5.4$  liters/kWh

$WUE_{SOURCE} = 4.9$  liters/kWh if energy from  
720 kW PV (10.5%) is included

using EWIF 4.542 liters/kWh for Colorado





## **Otto Van Geet, PE**

Principal Engineer, NREL

[Otto.vangeet@nrel.gov](mailto:Otto.vangeet@nrel.gov)

# Notice

This research was performed using computational resources sponsored by the U.S. Department of Energy's (DOE) Office of Energy Efficiency and Renewable Energy and located at the National Renewable Energy Laboratory under Contract No. DE-AC36-08GO28308. Funding provided by the Federal Energy Management Program. The views expressed in the presentation do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the presentation for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.