



# Voltage Regulation with Customer-Sited Resources

EUCI Hawai'i Power Summit 2017

Julieta Giraldez


Honolulu, Hawaii

December 1<sup>st</sup>, 2017

NREL/PR-5D00-70562

# HECO/NREL CRADA -Voltage Regulation Operating Strategies (VROS) Project

- **Objective:** simulation of feeder operations with advanced inverter grid support functions (GSF) to understand operational and customer curtailment impacts
- **Approach:** Add secondary circuits to two HECO feeders and use of annual quasi-static time-series analysis with various GSF (volt-VAR, constant power factor (CPF) and volt-watt) and varying PV penetration levels
- **Metrics**
  - Annual energy PV curtailment to all rooftop PV customers with advanced inverters
  - Increase in reactive power demand at the feeder-head from GSF
  - DeltaV metric for the highest-voltage week of the year



$$\Delta Vratio = \frac{V_{\max, AI} - V_{\min, AI}}{V_{\max, baseline} - V_{\min, baseline}}$$

# Summary of Findings from VROS Study

- **Final report**
  - <https://www.nrel.gov/docs/fy17osti/68681.pdf>
- **Volt-Var benefits over CPF 0.95**
  - Volt-Var is always as effective or more than CPF 0.95 in reducing over-voltages
  - Volt-Var results in significantly less reactive power absorption (good for utilities)
  - Volt-Var results in less PV kWh curtailment (good for customers)
- **Activating GSF in rooftop PV systems**
  - With reactive power priority, as opposed to active power priority, is recommended to avoid momentary over-voltages
  - Have no adverse impact in legacy utility voltage regulation equipment
  - Do not fix voltage violations due to existing legacy PV systems with no GSF

# Summary of Findings from VROS Study



- **Volt-Var is recommended to be used in combination with Volt-Watt to protect the system from over-voltages**
  - Results in more total customers able to interconnect
  - Can avoid the need for traditional upgrades

➤ Max. PV curtailment values much lower than expected

➤ Volt-Watt showed minor increase in PV curtailment

➤ Annual curtailment < 0.5% for 95% of customers

➤ Annual curtailment < 5% for remaining 5% of customers



# Caveats and Additional Scope

- Secondary low-voltage circuits are approximated and modeled up to the customer meter, but further voltage drop/rise could occur between the meter and the PV system generator terminals
  - *The field data from the advanced inverter pilot project is expected to calibrate and validate the findings of this VROS Project, including analyzing the behind-the-meter voltage rise impacts on kWh curtailment*
- PV penetration cases include all PV systems interconnected with the ability to export (as in NEM or customer-grid-supply (CGS) tariffs offered by the Companies')
  - *BS modeling including customer-self-supply*
- DER Parties concern about % customer energy reduction
  - *BS and load control impact on kWh curtailment*
  - *Update future scenarios with non-exporting tariffs (VROS models all PV systems exporting!)*
  - *Pilot project to verify kWh reduction from Volt-Watt*

# Advanced Inverter Pilot Project Overview

- NEM customers offered ability to connect without paying for secondary system upgrade in exchange for participating in the Advanced Inverter Pilot
- Objective: Field validation of inverter-based voltage regulation functions
  - Investigate impacts on feeder voltages (mainly secondaries)
  - Investigate curtailment impacts on PV kWh production
  - Validate VROS project feeder models with field data
  - Confirm that there are no undesired interactions among inverters or between inverters and utility equipment
- Functions under test:
  - Non-unity fixed power factor (FPF) operation
  - Volt-var control (VVC)
  - Volt-watt control (VWC)
  - Combinations: FPF+VWC, VVC+VWC
- Plans to expand this project to a larger number of customers

# Existing pilot data collection points


Substation  
SCADA

Grid2020

AMI

Inverter AC & DC

Irradiance



- Irradiance: 1-second intervals (selected locations)
- Inverter measurements: V, P, Q, pf, frequency, etc at inverter terminals
  - SolarEdge: 1-second intervals; Enphase: 5-minute intervals
- AMI: V, P, Q at customer meter; 1-minute intervals
- Grid2020: V, P, Q on LV side of transformer; 1-minute intervals
- Feeder SCADA data (V, P, Q, PF, LTC setting)
- All four data streams operational as of August
- Live feed to NREL's ESIF and remote control of GSF for participants

# Additional Research Questions

- How will utility and customer impacts of rooftop PV with GSF change with different scenarios of BS deployment?
- How will the charging and discharging of distributed BS under non-exporting and smart export tariffs affect day and night-time voltages?
- How much will GSF be activated with distributed BS?
- Can load control be used to minimize customer kWh curtailment from GSF?



# Thank you!

[julieta.giraldez@nrel.gov](mailto:julieta.giraldez@nrel.gov)

[www.nrel.gov](http://www.nrel.gov)

This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and the Hawaiian Electric Company. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

