

JACKSONVILLE 2019

EVALUATING THE INCIDENT ENERGY OF ARCS IN PHOTOVOLTAIC DC SYSTEMS: COMPARISON BETWEEN CALCULATED AND EXPERIMENTAL DATA

ESW2019-13

William Sekulic, P.E., NREL

Peter McNutt, P.E., NREL

NREL/PR-5K00-73213



IEEE IAS ELECTRICAL SAFETY WORKSHOP

Outline

- PV Solar System Characteristics
- DC Incident Energy –
 - NFPA 70E [1],
 - Maximum Power [2],
 - Stokes/Oppenlander [3]
- PV Solar Arc Experiments
- Comparison – Modeled vs. Measured Data
 - (order of magnitude difference)



Why Are We Discussing Arc Energy Hazards in PV Systems?



550 MW PV Plant [4]

- Ensure workers wear proper PPE but are not over protected
- States & Utilities looking to increase RE portfolios
- PV Systems in the hundreds of megawatts
- Thousands of acres
- Largest PV inverters approximately 1-MW



Not All DC Systems Are the Same

- PV Systems are different than other types of DC systems
 - e.g., Capacitors, Transit Systems, Batteries, ...
- Ensure PV workers appropriately protected from the hazards
- Studies should be conducted on each type of DC system (IEEE-1584 [5])



DC Laser Supply, LLNL NIF




DC Transit System, NREL



Battery Bank, NREL

Why is PV Incident Energy Different?

- Solar DC Systems have unique characteristics
- PV Systems are current and voltage limited
- PV Incident Energy Calculations are more than Voltage * Current * Time



Source: NREL




PV Characteristics

- Solar System Operational Parameters
- Environmental Parameters
- How to Determine Maximum Voltage, Current
- Arc Parameters




Typical PV System Operating Parameters

- Current and Voltage IV Curve
- Maximum Power (Pmp) ~ 915 W
- Max. Power Current (Imp) ~ 6 A
- Short-Circuit Current (Isc) ~ 7 A
- Max. Power Voltage (Vmp) ~ 155 V
- Open-Circuit Voltage (Voc) ~ 190 volts



Typical PV Module Operating Curves

A **SUNNIER** array produces more energy



A **COOLER** array produces more energy

NEC Table 690.7(A)

[12]



Sizing a PV String

Typical Sizing Tool [6] (most string inverter manufacturers offer a sizing tool)

Select your system's parameters

System Components

Inverter Model | Inverter 10kw (240VAC) |

- MPPT Setting: Separate MPPTs Combine to MPPT1

- Max PV System Voltage (Voc): 600V 1,000V

PV Module

- Manufacturer | Module MFG |

- Model [series] | 300 Watt Module |

Ambient Daytime Temperatures °F °C

- Record Cold | -25 .. -23°C |

- Average Hottest | 33 .. 35°C |





MPP1 Configurations (18A)

STRINGS

	1	2
4	1241	2483
5	1552	3104
6	1862	3724
7	2173	4345
8	2483	4966
9	2793	5587
10	3104	6207
11	3414	6828

String sizing dependent on:

- Inverter parameters
- Module parameters
- Local weather

-  Array could be larger (DC:AC < ~80%)
-  Optimal Configuration
-  Array may be Oversized (DC:AC > ~118%)
-  Max PV Current > Max Usable Input Current

In Denver, record low was -25°C [7], string limited to 11 modules (Voc ~ 592 V)

In Phoenix, record low was +1°C, string limited to 12 modules (Voc ~ 596 V)




PV System - Possible DC Arc Locations

Most faults can be categorized as:

- Line to Ground
- Line to Line
- Module to Module
- String to String

Note: *String fuses protect against backfeed & array faults*



Source: NREL


PV System – Resistance

Typical Power-Voltage Curve

- 1400W System

Resistance of PV System

- 45 ohms at MPPT



IV Curve – 1400W PV System, NREL

DC Arc Energy Calculations

- Losses and Error in Incident Energy Models for PV Systems
- NFPA 70E, Annex D[1]
- Maxim Power Incident Energy [2]
- Stokes/Oppenlander [3]



PV Arc Energy Calculations

- Heat Transfer Assumptions
 - Light, Heat, Sound Energy Assumed to all contribute to Incident Energy [3]
 - No losses accounted for in models
- PV Systems Don't Operate at Maximum Power During Faults
 - PV Modules and Systems **must** operate along their IV Curve
 - During arc events, PV system voltage will be decreased



DC Incident Energy Models – 70E Annex D, D.5 [1]

$$I_{arc} = 0.5 * I_{bf} \quad (1)$$

$$IE_m = \frac{(0.01 * V_{sys} * I_{arc} * T_{arc})}{D^2} \quad (2)$$

where:

V_{sys} – voltage system (volts)

I_{arc} – current arc (amperes)


I_{bf} – bolted fault current (amperes)

Z_g – arc gap (cm)

T_{arc} – arc time (seconds)

D – working distance (cm)

IE_m – incident energy max power (W/cm^2)



PV IV curve (NREL) - Source NREL

DC Incident Energy Models – Maximum Power (Doan) [2]

$$E_{I.E.} = \frac{(0.239 * V_{mp} * I_{mp} * t_{arc})}{4 * pi * d^2} \quad (3)$$

where:


V_{mp} – open circuit voltage (volts)

I_{mp} – short circuit current (amperes)

t_{arc} – arc time (seconds)

d – working distance (cm)

$E_{I.E.}$ – incident energy (w/cm²)



PV IV curve (NREL) - Source NREL

DC Incident Energy Models – Stokes/Oppenlander [3]

$$I_t = 10 + 0.2 * Z_g \quad (4)$$

$$V_{arc} = (20 + 0.5348 * Z_g) * I_{arc}^{0.12} \quad (5)$$

$$R_{arc} = \frac{(20+0.5348*Z_g)}{I_{arc}^{0.88}} \quad (6)$$

$$E_{arc} = I_{arc}^2 * R_{arc} * t_{arc} \quad (7)$$

$$E_{I.E.} = \frac{E_{arc}}{(4*pi*d^2)} \quad (8)$$

where:

V_{arc} – voltage arc (volts)

I_{arc} – current arc (amperes)


Z_g – arc gap (mm)

R_{arc} – arc resistance (ohms)

d – working distance (mm)

E_{arc} – energy (watt-seconds)

$E_{I.E.}$ – incident energy (w/cm²)




PV IV curve (NREL) - Source NREL

Arc Energy Testing Apparatus

- Voltage and Current Monitoring
- Arc Energy Sensors
- Arc Device
- Future Upgrades



Arc Device - Electrodes




DC Arc Device, NREL

- Linear Motion Stage
- Insulating Materials
- Copper Electrodes
- Arc Gap – 0.01” to 2.00” – Adjustable

Arc Device - Physical

- High Voltage Wiring
- Pure Copper Electrodes (1/4" diameter)
- Initial Tests were started shorted



DC Arc Device, NREL Source: NREL

Calorimeters – Copper Discs


- 3” diameter, 1/16” thick pure copper discs
- Type K- Thermocouples
- Precision Weighed
- Verified Readings for Temperature ($\pm 0.05^{\circ}\text{C}$)
- Insulated, Painted Flat Black
- Built and calibrated to ASTM/F1959/F1959 ,
ASTM/E457-08, [8],[9]



Copper Calorimeter Discs, NREL

Source: NREL

Arc Device - Upgrades



DC Arc Device, Upgrades, NREL

- Electrodes: 3/8" Diameter
- Other Configurations – Rectangular, Round
- Ceramic Insulated Holders

Arc Device - Upgrades

- Other Configurations – Rectangular, Round, Direction
- Adjustable Bus and Box Configurations



Source: NREL


Arc Energy Experimental Data

- Small Systems < 20kW DC Arc Event Data
- Comparison to Modeled Data



PV Arc Event – Imposed on Operating IV Curve

- **Red circles** – DC Arc Event
- Never reached Maximum Power Point




Arc Data Superimposed on Operating IV Curve, NREL



Arc Event vs. IV Operating Point

- **Arc Event** – 25 seconds
- Points Fall Well Below MPPT.
(Red Oval – labeled Arc Event)
- Inductive Kick when disconnected
- Arc Resistance is < 20 ohms
 - Significantly less than MPPT resistance
 - Non-zero fault resistance

$I_{sc} = 7$ amps $I_{arc} = 6.9A$
 $V_{oc} = 190$ volts $V_{arc} = 75V$




Arc Data Superimposed on Operating IV Curve, NREL



Arc Event – Voltage and Current Data


- Working Distance: 22.8 cm (9 inch)
- **Current Fairly Constant**
 - $I_{sc} = 18$ amps
 - $I_{arc} = 18$ amps
- **Voltage Varies**
 - $V_{oc} = 650$ VDC
 - $V_{arc} = 75$ VDC (95 Max)



Arc Voltage and Current, 10 Second Arc, NREL

Arc Event – Measured Incident Energy

- **Temperature Rise (Energy)**
 - Less than 0.05°C/SecondOr
 - 0.03 cal./cm² over 2 seconds
- Less Energy than 500 watt Calibration Lamp (Quartz Halogen)
 - 12" distance



Arc Calorimeter Data, 5kW PV System, 22.8cm (9 inch)
Working distance, 10 Second Arc, NREL

Arc Testing Results – Experimental vs Models

Test#	Power (Watts DC)	Work Dist (cm)	NREL Data (cal/cm ²)	70E (cal/cm ²)	Stokes/Oppenlander (cal/cm ²)	Maximum Power (cal/cm ²)	Error (Multiplier)	Error (%)
			<i>Experimental</i>	<i>Modeled</i>				
1	8365	46	0.0043	0.053	0.076	0.090	12	-92
2	8552	46	0.0092	0.055	0.078	0.093	6	-83
3	8690	46	0.0077	0.056	0.079	0.094	7	-86
4	8843	23	0.0299	0.227	0.322	0.380	8	-87
5	8875	23	0.0271	0.227	0.323	0.380	8	-88
6	8703	15	0.0354	0.501	0.713	0.843	14	-93
7	11549	46	0.0196	0.079	0.105	0.154	4	-75

Notes:

Tests Run at NREL, Golden, Colorado

Voc around 650VDC, Run 7 at 460VDC

Isc around 18 amps, Run 7 at 36 amps

**** All Experimental Arc Data is approximately 10 times less than modeled data ****



Data Discussions

- Arc Energy Modeled vs Experimental
- Understanding Modeled parameters
- Future Work



Arc Models – Compared to Experimental Data

Model Data

- Assume All Energy Transferred to Worker
- Use Maximum Power Voltage and Current or higher
 - Most Use Wrong Voltage
 - Most Use Wrong Current

Experimental Data

- Thermal Energy Transferred to Sensors (There are losses)
- Follow IV Curve and Depend Largely on Arc Resistance for Operating Point
- **** Arc Follows IV Curve ****

Arc Follows IV Curve



Arc Models – Parameters

Model Data

- Voltage
 - Either Open Circuit or Max Power
- Current
 - Use either Short Circuit or Max Power

Experimental Data

- Voltage
 - Not probable for Solar Device to operate at these points during arc
- Current
 - Operates slightly less than **I_{sc}** or Short Circuit Current



Future Work – NREL PV DC Arc Testing

- Build new Arc Jig
 - Using Ceramic Electrode Holders
 - ½” expendable copper tips
 - Allow for different bus configurations and electrode tips
- Improve Temperature Data Collection
 - New faster logging circuitry
 - New calorimeters, more sensitive
- More Test data for 5-30 kW PV strings and systems
- Help Improve and/or change 70E calculation methodology (dependent on DC generation type)



Need Models for the Different DC Systems

- IEEE 1584 may need to develop models for the different DC systems:
- PV, Capacitors, Fuel Cells, Batteries, DC power supplies...
 - Different Operating Characteristics



550 MW PV Plant [4]



Battery Bank, Source: NREL



Fuel Cell, Source: NREL



DC Laser Supply, Source: LLNL NIF

Other Relevant PV DC Arc Testing Work

EPRI PV DC arc model validation work:

High Power – 1MW PV system DC Arc experimental data

- Direct Current Arc-Flash Hazards of Solar Photovoltaic Systems [\[10\]](#)
- DC Arc Flash on Photovoltaic Equipment [\[11\]](#)



Acknowledgements

- Heath Garrison - NREL
- Ingrid Repins – NREL
- Teresa Barnes - NREL
- Byron McDanold - NREL
- Greg Perrin - NREL
- Dan Doan – Dupont
- Gary Dreifuerst – LLNL-retired

This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Solar Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.



References

- [1] Standard for Electrical Safety in the Workplace, NFPA 70E, 2018.
- [2] D. Doan, “Arc Flash Calculations for Exposures to DC Systems,” IEEE Transactions of Industry Applications, Vol. 46, No. 6, November/December 2010.
- [3] R.F. Ammerman, T. Gammon, P.K. Sen, “DC-Arc Models and Incident-Energy Calculations,” IEEE Transactions of Industry Applications, Vol. 46, No. 5, September/October 2010.
- [4] BHE Renewables.
- [5] IEEE Std 1584 2018 – IEEE Guide for Performing Arc-Flash Hazard Calculations, 2018.
- [6] Fronius String Configuration Tool: <https://www3.fronius.com/froniusdownload/tool.html>
- [7] Solar ABCs Solar Design Temps: www.solarabcs.org/about/publications/reports/expedited-permit/map/map_intro.html
- [8] ASTM/F1959/F1959 – 14, “Standard Test Method for Determining the Arc Rating of Materials for Clothing,” January 2017.
- [9] ASTM E457 08(2015) – Standard Test Method for Measuring Heat Transfer Using a Thermal Capacitance (Slug) Calorimeter
- [10] Direct Current Arc-Flash Hazards of Solar Photovoltaic Systems, EPRI, October 2018, <https://www.epri.com/#/pages/product/000000003002014641/?lang=en-US>
- [11] DC Arc Flash on Photovoltaic Equipment, EPRI, June 2018, <https://www.epri.com/#/pages/product/000000003002014124/?lang=en-US>
- [12] P. McNutt, W. Sekulic, G. Dreifuerst, Solar PV DC Systems: Basics & Safety, Fort Worth, TX, IEEE ESW 2018.
- [13] EFCOG Best Practices - #194: DC Arc-Flash Calculator, <https://efcog.org/best-practices/>



JACKSONVILLE 2019

Questions?

William Sekulic - NREL

bill.sekulic@nrel.gov

Peter McNutt – NREL

peter.mcnutt@nrel.gov



IEEE IAS ELECTRICAL SAFETY WORKSHOP