

# Performance Assessment of Low-GWP Refrigerated Reach-In Display Cases

Ramin Faramarzi (NREL)  
Alex Bulk (NREL)  
Steven LaBarge (ComEd)

# Objective

Evaluate daily energy savings of medium-temperature, reach-in refrigerated display cases featured with:

- Energy-efficient heat exchangers, fan motors, and lighting
- Environmentally friendly refrigerants R290, R513a



Photo from Alex Bulk, NREL

# Background

- Widespread use in convenience stores/restaurants/small supermarkets
- Little research has investigated energy use of medium-temperature, self-contained, reach-in cases with focus on low global warming potential (GWP) refrigerants
- U.S. Environmental Protection Agency phase-down of units using hydrofluorocarbon (HFC) refrigerants starting in 2020
- Need to promote high-efficiency fixtures that use environmentally friendly refrigerants



Photos from <https://www.nrel.gov/docs/fy22osti/80634.pdf>



# Properties of Refrigerants

Refrigerant	Saturated Liquid Density ( $\rho$ ) at 25°C (kg/m <sup>3</sup> )	Global Warming Potential	Liquid Specific Heat Capacity @ Const. Pressure ( $c_p$ ) at 25°C (kJ/kg K)	Vapor Specific Heat Capacity @ Const. Pressure ( $c_p$ ) at 25°C (kJ/kg K)	Enthalpy of Vaporization (kJ/kg)
R134a	1207	1301	1.425	0.851	234.7
R290	492	3	2.483	1.684	440.1
R513a	1134	573	1.412	0.881	194.8

**R290:** Higher refrigeration effect with nearly double enthalpy of vaporization, R290 can provide more effective cooling with reduced compressor run-time due to both lower density and higher heat transfer coefficient

**R513A:** Similar thermodynamic properties to R134a but with less than half GWP

# Case Specifications



Photo from Alex Bulk, NREL

## R290 Unit: EE Case A

- High-density polyurethane foam insulation
- Thermal-insulated glass doors
- Efficient fan motors
- Efficient lighting/controller
- No defrost (off-cycle)



Photo from Alex Bulk, NREL

## R134a Unit: Baseline

(R513a unit is same model)  
**EE Case B**

- Higher UA evaporator,
- Efficient fan motors
- Efficient lighting/controller

# Case Operational Parameters

Selection based on most compatible cases in size, refrigeration ratings, and electrical specifications

Case	Refrigerant	Defrost Cycle Frequency	Rated Cooling Output (Btu/h)*
Baseline	R134a	24 hours	7,680
EE Case A	R290	none	6,725
EE Case B	R513a	12 hours	7,727
Case	Merchandising Capacity (ft <sup>3</sup> )**	Evaporator Fan Operation	
Baseline	48.29	Continuous	
EE Case A	49.15	1 min every 6 min when compressor is off Continuous when compressor is on	
EE Case B	48.29	With compressor cycling	

\*All specs taken from product spec sheets

\*\*Compressor spec sheet (cooling capacity using ARI (Air Conditioning and Refrigeration Institute standard) @ 45°F evap temp)

# Experimental Methodology

---

# Evaluation Protocols

## Two areas of evaluation:

1. Energy consumption: total and components over 24 hours
2. Performance: product temperatures, air temperatures

## Standards

- ANSI/ASHRAE 72-2018 (overall setup, procedure)
- ANSI/NSF 7-2016 (uses ASHRAE 72)
- ANSI/AHRI 1200-2013 (capacity/energy calculation, lower temperature limit)
- FDA food code (upper temperature limit)



# Laboratory and Environmentally Controlled Evaluation Chamber




Photos from NREL.gov

Below: Environmental chamber



Photos from Alex Bulk, NREL

Right: Map of experimentation facility:



# Power and Energy Measurements and Configuration

Display Case Power


Total Power

Component Power

Photos from Alex Bulk, NREL



Wattnode  
Power  
Meter Box



Data Acquisition /  
Analytics

Current transformers instrumented to:

1. Total refrigeration system
2. Total lighting/controls
3. Compressor
4. Condenser fan motor
5. Evaporator fan motor(s)

# Shopper Traffic Emulation


- Door actuators were installed on each door
- Doors were opened every 10 minutes at  $\sim 90^\circ$  angle for 6 seconds
- Doors opened sequentially from left to right
- Door openings for only 8-hour period of 24-hour test




Photos from Alex Bulk, NREL

# Replicating Thermal Mass of Food Product (Filler Material)


Filler material  
water bottles:



Orientation of bottles and simulators  
on shelf:



Photos from Alex Bulk, NREL



# Deviations From ASHRAE 72/AHRI 1200 Standard

Deviation	Purpose
Filler material: H <sub>2</sub> O bottles used instead of wood and propylene glycol (PG)	PG safety issues, rectangular wood blocked off airflow
Filler material: bottles only fill max ~50% internal volume, not 70–90%	Bottles are cylindrical with space in between to allow airflow
Measured condensate mass	Evaluate latent load inside case
No refrigerant pressure taps, surface thermocouples	Avoid tampering with refrigerant lines to assess case in purchased condition
Additional air temperature locations	More accurate averages

# Experimentation Prep/Setup

## Prior to Data Collection:

- Run cases until reach steady state:
  - Adjust set point temp until product simulators complied with FDA and AHRI
- Maintain cases at steady state for 12-hour test:
  - Ensure conditions maintained, doors open on schedule, etc.




Photo from Alex Bulk, NREL

# Methodology



Photos from Alex Bulk, NREL

- Start test and evaluate case parameters over 24-hour period
- 1-second data collection
- Screen raw data
- Post-process validated data
- Perform repeatability test for convergence

# Results

---




# Total Daily Energy and Mean Power

Energy/  
Power

Compressor-on  
time


## Total Mean Daily Energy



**61.8%  
Savings**

**32.6%  
Savings**

## Mean On-Cycle Power Draw




**38.0%  
Reduction**

**4.12%  
Reduction**


# Component Energy and Mean Power Results at ASHRAE Environmental Conditions

*% of Total Energy by Compressor*

## Component Mean Daily Energy



## Component On-Cycle Power Draw



# Mean, Max, Min Product Temperatures Over 24 Hours

## Mean Temperatures:




**Baseline: 37.4°F / 3.00°C**

FDA/AHRI  
Upper Limit

**EE Case A: 37.2°F / 2.90°C**

**EE Case B: 37.4°F / 3.02°C**

AHRI  
Lower Limit



# Conclusions

- EE Case A (R290) consumed 61.8% less daily energy than the baseline (4.30 vs. 11.3 kWh/day)
  - Savings attributed to a combination of energy efficiency components and thermodynamic properties of R290
- EE Case B (R513a) consumed 32.6% less daily energy than the baseline (5.79 vs. 11.3 kWh/day)
  - Savings mainly attributed to energy efficiency components since generally, thermodynamic properties of R134a and R513a are very similar



# Thank You!

## We will now move to Q&A

[www.nrel.gov](http://www.nrel.gov)

NREL/PR-5500-84783

This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Support for the work was also provided by ComEd under agreement # TSA-19-01159. The views expressed herein do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

# Case Selection Criteria

1. Number of shelves/doors: 4 shelves/3 doors
2. Similar discharge temp range: around 38°F (medium temp.), adjustable for altitude
3. Similar length within  $\pm 3$  in.: True (78.6 in.), HMC (78.5 in.)
4. Similar internal volumetric capacity within  $\pm 5$  ft<sup>3</sup>: True (65.7 ft<sup>3</sup>), HMC (62.1 ft<sup>3</sup>)
5. Door type (swing)
6. Number of condensing units: 1
7. Same refrigeration system: fin & tube cond/evap, 1-speed comp, capillary tube
8. Same V/Hz/phase: 115 V/60 Hz/1-phase
9. Compressor size/type: ½ HP reciprocating
10. Condensing unit and lighting/controls all on one circuit/plug
11. DOE CCMS (Compliance Certification Management System)-database rated



R134a (Left), R513a (Center): Howard McCray (HMC) Model GR75  
R290 (Right): True Manufacturing Model GDM-72-HC~TSL01

# Temperature Measurement Specifications

Location	Type	Model #	Distributor	Accuracy
Product Simulator, Internal Air, and Chamber Dry-Bulb Temperature Measurements	TC Type-T 1/16" probe	TMQSS-062U-6	Omega Engineering	$\pm 0.5^{\circ}\text{C}$ ( $\pm 0.9^{\circ}\text{F}$ )
Chamber Dew Point Temperature	Chilled Mirror Dew Point Hygrometer	DewTrak II DPS3	EdgeTech	$\pm 0.22^{\circ}\text{C}$ ( $\pm 0.4^{\circ}\text{F}$ )
Refrigerant Surface Temperatures	TC Type-T Surface Thermocouple	SA1-T-SRTC	Omega Engineering	$\pm 0.5^{\circ}\text{C}$ ( $\pm 0.9^{\circ}\text{F}$ )

# Power and Energy Measurements and Configuration


Location	Brand/Model #	Type	Accuracy
Case Total Plug and Compressor Power/Voltage/Current/Power Factor	Continental Control Systems/WMC-3Y-208-MB, Accu-CT ACTL-0750	Wattnode power meter, 20-A current transformer	±0.5%
Condenser Fan, Evaporator Fan(s), Lighting, and Controller Power/Voltage/Current/Power Factor		Wattnode power meter, 5-A current transformer	



# Stabilized Chamber Conditions

Upper and lower limits for chamber dry bulb temperatures and dew point temperatures (DBT and DPT ranges based on range for ASHRAE DBT and WBT)

Sensor	Set Point	Upper Limit	Lower Limit
$T_A$ DBT	24°C / 75.2°F	25°C / 77°F	23°C / 73.4°F
$T_B$ DBT	Same as above	26.67°C / 80°F	21.33°C / 70.4°F
$T_A$ DPT	15.42°C / 59.76°F	17.42°C / 30.94°F	13.23°C / 55.81°F



# Set Point Correction

Adjusted compressor cut-in/cut-out temperatures and mean simulator temps (AHRI requires between 36°F/2.22°C and 40°F/4.44°C):

(Due to lowered air density at altitude)

CASE	Cut-In Temperature (°F/°C)	Cut-Out Temperature (°F/°C)	Steady-State Mean Product Simulator Temperature (°F/°C)
Baseline	38/3.33	30/-1.11	37.40 ± 0.04/3.00 ± 0.02
EE Case A	35/1.67	30/-1.11	37.22 ± 0.05/2.90 ± 0.03
EE Case B	39/3.89	31/-0.56	37.44 ± 0.05/3.02 ± 0.03

# Results Summary of Component Energy at ASHRAE Conditions

## Component Mean Daily Energy

Component	Baseline (kWh/day)	% Total	EE Case A (kWh/day)	% Total	EE Case B (kWh/day)	% Total
Compressor	6.21 ± 0.02	55.08%	2.89 ± 0.01	67.41%	5.87 ± 0.04	73.30%
Condenser Fan	0.94 ± 0.00	8.31%	0.13 ± 0.00	2.95%	0.45 ± 0.00	5.67%
Evaporator Fans	1.07 ± 0.00	9.47%	0.24 ± 0.01	5.56%	0.26 ± 0.01	3.25%
Lighting/ Controller	3.06 ± 0.00	27.14%	1.03 ± 0.00	24.08%	1.42 ± 0.00	17.77%

## Component Mean On-Cycle Power Draw

Component	Baseline (W)	% Total	EE Case A (W)	% Total	EE Case B (W)	% Total
Compressor	662 ± 325	70.92%	469 ± 205	84.22%	802 ± 370	84.27%
Condenser Fan	100 ± 49	10.66%	21 ± 9	3.73%	62 ± 29	6.51%
Evaporator Fans	44 ± 1	4.76%	24 ± 12	4.34%	28 ± 14	2.98%
Lighting/ Controller	127 ± 1	13.65%	43 ± 0.1	7.72%	59 ± 0.2	6.23%

# Baseline Results – Energy and Condensate at All Environmental Conditions



## Baseline Case Total Energy Consumption

- Higher than expected for this case

## Baseline Case Condensate Mass Produced

- Not required by ASHRAE but done in case customer uses condensate pump

Report does not compare individual cases and only compares across environmental conditions to avoid manufacturer concerns



# Mean, Max, Min Product Temperatures Over 24 Hours

**Baseline**

**Warmest Simulator**

**EE Case A**


**Coldest Simulator**

**EE Case B**

FDA/AHRI Upper Limit


Average Simulator

AHRI Lower Limit



# Baseline Results – Component Energy Consumption at All Environmental Conditions


## Baseline Case Component Energy Consumption (kWh/day)



# Baseline Results – Transient Energy Consumption at ASHRAE Environmental Conditions

## Baseline Case Total and Component Power Consumption Over 24 Hours

- Zoomed in over 1.5 hours (around end of door opening period)



# Baseline Results – Normalized Energy Consumption at All Environmental Conditions

Energy consumption normalized to internal volumetric capacity and time between defrost (for ComEd to compare cases):


CONDITION	Total Energy Consumption (kWh/day)	Total Energy Consumption Corrected to Time-Between-Defrost (kWh/day)	Total Energy Consumption Normalized to Internal Volume (kWh/m <sup>3</sup> day)	Total Energy Consumption Corrected to Time-Between-Defrost and Normalized to Internal Volume (kWh/m <sup>3</sup> day)
January	10.50 ± 0.01	10.99 ± 0.03	7.68 ± 0.01	8.04 ± 0.02
July	10.34 ± 0.06	10.87 ± 0.03	7.56 ± 0.05	7.95 ± 0.02
ASHRAE	11.26 ± 0.01	11.82 ± 0.08	8.23 ± 0.01	8.64 ± 0.06



# Baseline Results – Transient Temp Performance at ASHRAE Conditions

## Baseline Case Product and Internal Air Temps Over 24 Hours

- Average product simulator temperature, coldest average, warmest average, coldest peak, and warmest peak product simulator temperature (and AHRI limits)
- Average of evaporator discharge grill temps, internal ambient (case geometric center), and evaporator fan inlet
- Air temps, but zoomed in over 1.5 hours



# Baseline Results – Product Simulator Temps at ASHRAE Conditions

## Baseline Case Average Product Simulator Temperatures

- Shown for all environmental conditions in report

(Standard only specifies the average of all simulators to be within the required range, not individual)

### Top Shelf

Rear:	2.98°C	-0.31°C	4.11°C
Front:	4.97°C	2.37°C	5.98°C

### Middle Shelf

Rear:	1.56°C	-0.38°C	2.40°C
Front:	2.97°C	1.12°C	4.07°C


### Bottom Shelf

Rear:	2.33°C	1.53°C	3.66°C
Front:	5.02°C	3.52°C	6.23°C

# EE Case A Results – Energy and Condensate at All Environmental Conditions


## EE Case A Total Energy Consumption

- Lower than expected for this case based on CCMS Data




## EE Case A Condensate Mass Produced

- Not required by ASHRAE but done in case customer uses condensate pump



# EE Case A Results – Component Energy Consumption at All Environmental Conditions



## EE Case A Component Energy Consumption (kWh/day)



# EE Case A Results – Transient Energy Consumption at ASHRAE Environmental Conditions

## EE Case A Total and Component Power Consumption Over 24 Hours

- Zoomed in over 1.5 hours (around end of door opening period)



# EE Case A Results – Normalized Energy Consumption at All Environmental Conditions


Energy consumption normalized to internal volumetric capacity and time between defrost (for ComEd to compare cases)

CONDITION	Total Energy Consumption (kWh/day)	Total Energy Consumption Corrected to Time-Between-Defrost (kWh/day)	Total Energy Consumption Normalized to Internal Volume (kWh/m <sup>3</sup> day)	Total Energy Consumption Corrected to Time-Between-Defrost and Normalized to Internal Volume (kWh/m <sup>3</sup> day)
January	3.53 ± 0.02	3.53 ± 0.02	2.54 ± 0.01	2.54 ± 0.01
July	3.63 ± 0.07	3.63 ± 0.07	2.61 ± 0.05	2.61 ± 0.05
ASHRAE	4.30 ± 0.00	4.30 ± 0.00	3.09 ± 0.00	3.09 ± 0.00

# EE Case A Results – Transient Temp Performance at ASHRAE Environmental Conditions

## EE Case A (R290 case) Product and Internal Air Temps Over 24 Hours

- Average product simulator temperature, coldest average, warmest average, coldest peak, and warmest peak product simulator temperature (and AHRI limits)
- Average of evaporator discharge grill temps, internal ambient (case geometric center), and evaporator fan inlet
- Air temps, but zoomed in over 1.5 hours



# EE Case A Results – Product Simulator Temps at ASHRAE Environmental Conditions

## EE Case A Average Product Simulator Temperatures

- Shown for all environmental conditions in the report

### Top Shelf

Rear:	2.07°C	-0.29°C	1.86°C
Front:	4.27°C	1.74°C	5.02°C

### Middle Shelf

Rear:	1.54°C	-0.50°C	2.49°C
Front:	3.46°C	0.96°C	4.20°C

### Bottom Shelf

Rear:	3.96°C	1.77°C	5.13°C
Front:	5.13°C	3.93°C	5.75°C




# EE Case B Results – Energy and Condensate at All Environmental Conditions

## EE Case B

### Total Energy Consumption


- Case has not been rated, so we had no expectations of energy consumption



## EE Case B

### Condensate Mass Produced


- Not required by ASHRAE but done in case customer uses condensate pump



# EE Case B Results – Component Energy Consumption at All Environmental Conditions

## EE Case B


### Component Energy Consumption (kWh/day)



# EE Case B Results – Transient Energy Consumption at ASHRAE Environmental Conditions

## EE Case B Total and Component Power Consumption Over 24 Hours

- Zoomed in over 1.5 hours (around end of door opening period)



## EE Case B Results – Normalized Energy Consumption at ASHRAE Environmental Conditions


Energy consumption normalized to internal volumetric capacity and time between defrost (for ComEd to compare cases)

CONDITION	Total Energy Consumption (kWh/day)	Total Energy Consumption Corrected to Time-Between-Defrost (kWh/day)	Total Energy Consumption Normalized to Internal Volume (kWh/m <sup>3</sup> day)	Total Energy Consumption Corrected to Time-Between-Defrost and Normalized to Internal Volume (kWh/m <sup>3</sup> day)
January	6.13 ± 0.02	6.78 ± 0.00	4.48 ± 0.01	4.96 ± 0.00
July	6.42 ± 0.02	7.07 ± 0.02	4.70 ± 0.01	5.17 ± 0.02
ASHRAE	7.59 ± 0.03	8.32 ± 0.03	5.55 ± 0.02	6.09 ± 0.02

# EE Case B Results – Transient Temp Performance at ASHRAE Environmental Conditions

## EE Case B (R513a case) Product and Internal Air Temps Over 24 Hours

- Average product simulator temperature, coldest average, warmest average, coldest peak, and warmest peak product simulator temperature (and AHRI limits)
- Average of evaporator discharge grill temps, internal ambient (case geometric center), and evaporator fan inlet
- Air temps, but zoomed in over 1.5 hours



# EE Case B Results – Product Simulator Temps at ASHRAE Environmental Conditions

## EE Case B Average Product Simulator Temperatures

- Previous graphs and this table shown for all environmental conditions (except zoomed-in air temps)

### Top Shelf

Rear:	2.10°C	0.70°C	1.02°C
Front:	5.18°C	3.45°C	3.98°C

### Middle Shelf

Rear:	2.36°C	0.67°C	1.08°C
Front:	4.59°C	2.67°C	3.32°C

### Bottom Shelf

Rear:	3.40°C	2.68°C	3.06°C
Front:	5.49°C	4.01°C	5.38°C

# ComEd – CLEAResult Self-Contained Medium-Temperature Refrigerator Display Case Assessment

- Chamber DBTs and DPTs and measurement limits
- Refrigerant piping surface temperatures
- Piping surface temperatures zoomed in 1.5 hours around end of door-opening period

