


# Best Practices to Design, Retrofit, and Operate Efficient Data Centers





# Otto Van Geet

Principal Engineer, PE

National Renewable Energy Laboratory  
(NREL)


# Energy Efficient Data Center Strategies

- Thermal (environmental) guidelines
- Air management
- Free cooling
- Performance metrics
- Liquid-based cooling
- [www.energy.gov/femp/articles/best-practices-guide-energy-efficient-data-center-design](https://www.energy.gov/femp/articles/best-practices-guide-energy-efficient-data-center-design)

## Best Practices Guide for Energy-Efficient Data Center Design

Revised March 2024





## Thermal Guidelines for Data Processing Environments

Fifth Edition

ASHRAE Datacom Series

Data center equipment's environmental conditions should fall within the ranges established by ASHRAE as published in the *Thermal Guidelines*.

### Environmental Specifications (°F, °C)


		Recommended	Allowable			
		A1 - A4	A1	A2	A3	A4
Dry-Bulb Temp	Degree F	64.4 to 80.6	59 to 89.6	50 to 95	41 to 104	41 to 113
	Degree C	18 to 27	15 to 32	10 to 35	5 to 40	5 to 45
Humidity	RH	8% to 70% *	8% to 80% *	8% to 80% *	8% to 85% *	8% to 90% *

Source: ASHRAE. 2021. *Thermal Guidelines for Data Processing Environments, Fifth Edition*. <https://www.ashrae.org/technical-resources/bookstore/datacom-series>.

- Refer to ASHRAE for the high-level pollutants and max. rate of change for tape storage.
- If testing shows corrosion levels exceed these limits, then drops to 50% max.

**These environmental envelopes pertain to air entering the IT equipment**

**Conditions at SEA LEVEL**




Source: ASHRAE. 2021. *Thermal Guidelines for Data Processing Environments, Fifth Edition*. <https://www.ashrae.org/technical-resources/bookstore/datacom-series>.

# Equipment Environmental Specification


**Air inlet** to information technology (IT) equipment **is** the important specification to meet

Outlet temperature is *not* important to IT equipment



# Improve Air Management


- Typically, more air circulated than required
- Air mixing and short-circuiting leads to:
  - Low supply temperature
  - Low Delta T
- Use hot and cold aisles
- Improve isolation of hot and cold aisles
  - Reduce fan energy
  - Improve air-conditioning efficiency
  - Increase cooling capacity



Source: [www.energy.gov/femp/articles/best-practices-guide-energy-efficient-data-center-design](https://www.energy.gov/femp/articles/best-practices-guide-energy-efficient-data-center-design)

Hot aisle/cold aisle configuration decreases mixing of intake and exhaust air, promoting efficiency.

# Isolate Cold and Hot Aisles




Source: [www.energy.gov/sites/prod/files/2013/10/f3/eedatacenterbestpractices.pdf](http://www.energy.gov/sites/prod/files/2013/10/f3/eedatacenterbestpractices.pdf)



# Psychrometric Bin Analysis

## Boulder, Colorado TMY3 Weather Data



Source: [www.nrel.gov/docs/fy17osti/68218.pdf](http://www.nrel.gov/docs/fy17osti/68218.pdf)

# Estimated Savings

## Baseline

System	Direct expansion (DX) cooling with no economizer
Load	1 ton of cooling, constant year-round
Efficiency (Coefficient of Performance)	3
Total Energy (kWh/yr)	10,270

Results	Recommended Range		Allowable Range	
	Hours	Energy (kWh)	Hours	Energy (kWh)
Zone1: DX Cooling Only	25	8	2	1
Zone2: Multistage Indirect Evap. + DX (H80)	26	16	4	3
Zone3: Multistage Indirect Evap. Only	3	1	0	0
Zone4: Evap. Cooler Only	867	97	510	57
Zone5: Evap. Cooler + Economizer	6055	417	1656	99
Zone6: Economizer Only	994	0	4079	0
Zone7: 100% Outside Air	790	0	2509	0
<b>Total</b>	<b>8,760</b>	<b>538</b>	<b>8,760</b>	<b>160</b>
<b>Estimated % Savings</b>	-	<b>95%</b>	-	<b>98%</b>

# Data Center Metrics

## Data Center Metrics: The Green Grid PUE "Family"

### Energy

$$\text{Power Usage Effectiveness PUE} = \frac{\text{"Facility energy"} + \text{"IT energy"}}{\text{"IT energy"}} = \frac{\text{"Total energy"}}{\text{"IT energy"}}$$

$$\text{IT-power Usage Effectiveness ITUE} = \frac{\text{"IT energy"}}{\text{Total energy into the "Compute Components"}}$$

$$\text{Total-power Usage Effectiveness TUE} = \text{PUE} \times \text{ITUE}$$

$$\text{Energy Reuse Effectiveness ERE} = \frac{\text{"Facility energy"} + \text{"IT energy"} - \text{"Reuse energy"}}{\text{"IT energy"}}$$

### Sustainability (water and carbon)


$$\text{Water Usage Effectiveness WUE} = \frac{\text{"Annual site water usage"}}{\text{"IT energy"}} \left( \text{units } \frac{\text{L}}{\text{kWh}} \right)$$

$$\text{WUE}_{\text{source}} = \frac{\text{"Annual site water usage"} + \text{"Annual source energy water usage"}}{\text{"IT energy"}}$$


$$\text{Carbon Usage Effectiveness CUE} = \frac{\text{"Total CO}_2 \text{ emissions caused by total energy"}}{\text{"IT energy"}} \left( \text{units } \frac{\text{kgCO}_2 \text{eq}}{\text{kWh}} \right)$$

### Utilization (based on industry)

{Gflops, Transaction} per Watt





Assume ~20MW HPC system & \$1M per MW year utility cost.



# Cooling Efficiency

- Liquid conduits require 250 to 1,000 times less space than air conduits for transporting the same quantity of heat energy.
- Liquids require 10 to 20 times less energy to transport energy.
- Liquid-to-liquid heat exchangers have closer approach temperatures than liquid-to-air (coils), yielding greater efficiency and increased economizer hours.
- ASHRAE Technical Committee 9.9 liquid standards provide an excellent guide.


Heat Transfer		Resultant Energy Requirements			
Rate	$\Delta T$	Heat Transfer Medium	Fluid Flow Rate	Conduit Size	Theoretical Horsepower
10 Tons	12°F	Forced Air 	9217 cfm	34" Ø	3.63 Hp
		Water 	20 gpm	2" Ø	.25 Hp

Source: ASHRAE Technical Committee 9.9: Mission Critical Facilities, Data Centers, Technology Spaces and Electronic Equipment.  
<https://tpc.ashrae.org/?cmtKey=fd4a4ee6-96a3-4f61-8b85-43418dfa988d>.

# Increasing CPU Power – Transition to Warm Water Cooling

NREL believes increasing CPU power will:

- Drive transition to warm water cooling
- Transition from fans to pumps, saving energy
- Eliminate chillers for cooling
- Enable much greater waste heat reuse, saving water and displacing fossil fuel heating, reducing carbon emissions
- Reducing water usage through reduction of cooling towers and lowering overall system cooling infrastructure and operating costs.



Soft Limits & Temperature Regression of Air and Water.  
Source: Draft figure from ASHRAE TC 9.9, found on slide 43 of  
<https://tpc.ashrae.org/FileDownload?idx=2779ca57-3cbc-4f16-8484-bab38f9c1771>.

# Fanless Direct Liquid-Cooled Server Options

## Fixed Cold Plate

Photo by Werner Slocum,  
NREL 77629



## Data Center Metrics: The Green Grid PUE “Family”


### Energy

$$PUE = \frac{\text{"Facility energy"} + \text{"IT energy"}}{\text{"IT energy"}} = \frac{\text{"Total energy"}}{\text{"IT energy"}}$$


$$ITUE = \frac{\text{"IT energy"}}{\text{Total energy into the "Compute Components"}}$$

$$TUE = PUE \times ITUE$$

## Direct Immersion



Single Phase



Two Phase  
Image from Liquid Stack

# FEMP/NREL's Key Approach to Sustainable Data Centers

1. PUE: Reduce energy use by making systems as efficient as possible.
  - ***Maximize compute entering temperature while avoiding IT overheating to maximize energy efficiency!***
  - “Free” cooling to reduce or eliminate compressor (chiller, DX) based cooling:
    - a) Install direct liquid cooled computers that use warm water
    - b) Capture as much heat as possible directly to the liquid cooling system
  - Optimizing fan/pump speeds and UPS
2. ERE: Heat reuse – achieve lowest Energy Reuse Effectiveness possible
  - ***Maximize compute leaving temperature to maximize energy reuse!***
3. WUE: Reject as much remaining heat to dry coolers as possible
  - ***Maximize compute leaving temperature to maximize heat rejected dry!***
4. CUE: Maximize energy from renewable systems on site or within grid region
  - ***With the goal of 100% renewable energy 100% of the time.***

# Questions?

Otto Van Geet, 303-601-2045, [otto.vangeet@nrel.gov](mailto:otto.vangeet@nrel.gov)



Garage  
1,156 kW

CATS  
200 kW

OTF+  
50 kW

RSF B  
449 kW

RSF A  
408 kW

S&TF  
94 kW

Mesa  
720 kW

Parking  
524 kW

NREL PV Systems ~3,600 kW  
South Table Mesa Campus







NREL/PR-5R00-89134 • March 2024

This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the DOE Federal Energy Management Program. The views expressed do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the work for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.