



## Challenges

- Efforts on microgrids with **mixed-type DERs** (rotating machine-based, IBR-based (GFL+GFM))
- In 100% renewable microgrids, challenges are:
  - Low fault current contributions** by the IBRs, restricted by switch ratings and fault limiter
  - Varying fault current levels of DERs** due to the variability of the renewable resources.
- Reduced fault current results in complete **failure/delayed tripping** by overcurrent relays.
- Varying levels of the low fault current impacts the **threshold-based protection system** and relay coordination.


## Contribution

- Methodology to **partition the microgrid into multiple zones based on lines, buses, etc.** (regardless of the topology)
- Unique protection schemes for zone** with the best reliability
- Hierarchical structure** enabling relay coordination by assigning **different speeds** for zones.


## Zone 1 Protection







## Zone 2 and Zone 3 Protection



## Zone 4 Protection



- $I_{Th} = \alpha \times \sqrt{2} \times I_{rated} \sin[2\pi(n + D)/N]$ 
    - $\alpha$ : CT saturation factor (IEEE C37.110-2007)
    - $I_{rated}$ : Rated line current of ZoP
    - $N$ : Number of samples/cycle
    - $n$ : Index of sample
    - $D$ : Sample delay in communication
  - Avoid nuisance tripping:
    - a condition hold (counter=M)
    - $\alpha, N, D, M$  are 2, 100, 2, and 200, respectively.
  - $T_{air} = |\hat{V}_{pol}| |\hat{I}_{pol}| \cos(\angle \hat{V}_{pol} - \angle \hat{I}_{pol})$ 
    - $\alpha$ : CT saturation factor (IEEE C37.110-2007)
    - $\hat{I}_{pol}$ : Rated nodal current measured by  $n^{th}$  relay
  - Avoid nuisance tripping:
    - A condition hold (counter=M)
    - $\alpha, M$  are 2 and 200, respectively.
- VR-overcurrent tripping characteristics are employed in the relays situated in Zone 1 and Zone 4 as a backup protection system with proper relay coordination.



Mode	Rel.	Dep.	Sec.	Mode	Speed[s]
					max. min.
Grid-tied	98.26	98.12	98.27	Grid-tied	0.033 0.27
Islanded	97.77	97.63	97.78		
Overall	98.00	97.89	98.02	Islanded	0.033 0.32

### Performance of proposed protection scheme

- 1,620 cases** are simulated:
  - 1,150 cases of fault types, locations, and impedances
  - 470 fault-like cases (load/capacitor switching, solar irradiance drop/rise, etc.)

Type	F1(G) (ag) 0.01H	F2(B) (absG) 25G	F3(G) (bg) 15G	F4(H) (eg) 2H	F5(G) (bg) 20G	F6(H) (abG) 20G	F7(G) (ag) 0.05H	F8(H) (bg) 10G
Relay	R200, PCC-switch	R201, R202	R201, R201d	R205, BESS1-switch	R206, R207, R207d	R208, PV2-switch	R204, R204d	
Time[s]	0.17	0.033	0.033	0.21	0.09	0.033	0.19	0.033

F9(C) (ag) 0.01H	F10(H) (bc) 5G	F11(G) (ag) 2G	F12(H) (bc) 5G	F13(C) (ag) 10G	F14(H) (bc) 10G	F15(G) (ag) 2.5G	F16(H) (bc) 5G	F17(C) (ag) 5G
R202, R202d	R211, PV1-switch	R209, R209d	R210, R210d	R219, BESS2-switch	R212, R212d	R201d, R208, R207	R207d, R210d	R209, R210, R211
0.033	0.18	0.033	0.033	0.17	0.11	0.033	0.033	0.033

### Operating times for proposed protection scheme

## Future Work

- Improving the operating time of the protection schemes—especially for Zone 3—is considered for future work to further enhance the proposed protection scheme.