


Andy Walker, National Renewable Energy Laboratory (NREL)
 Vignesh Ramasamy, NREL
 Jal Desai, NREL

- Connectors have historically been viewed as essential—but relatively uninteresting—components of a PV system, with a functional role that has been overshadowed by the industry's focus on module efficiency and lower manufacturing and installation costs.
- Defective and degraded connectors affect system performance in profound ways, from power losses to increased O&M needs, to catastrophic failure and fire. In addition, degrading and failed connectors raise the specter of higher insurance rates, leveled cost-of-energy (LCOE) increases, and decreased confidence in the reliability of solar-generated power.
- To advance the science of connector reliability, the US Department of Energy has funded a collaboration of Sandia National Laboratories, National Renewable Energy Laboratories, Electric Power Research Institute with activities described on the project website: <https://energy.sandia.gov/programs/renewable-energy/photovoltaic-solar-energy/projects/pv-connectors/>.
- Overall, the objective of this project is to help drive the industry toward higher-quality connectors and improved installation practices, thus increasing the performance, reliability, safety and availability of the US solar infrastructure.
- Techno-economic analysis (TEA) data is collected in parallel with field data and industry interviews to quantify the impact of connector failure on PV lifecycle economic metrics, including energy yield, O&M expenses and leveled-cost-of-energy (LCOE). This work will include the modeling and analysis of power losses, O&M expenses and other soft costs related to failed connectors and will measure the impact of connector degradation and failure on a plant's LCOE.

Methodology:



References:

Walker et al., 2020. *Model of Operation-and Maintenance Costs for Photovoltaic Systems*. Walker, Andy, Eric Lockhart, Jal Desai, Kristen Ardani, Geoff Klise, Olga Lavrova, Tom Tansy, Jessie Deot, Bob Fox, and Anil Pochiraju. 2020. Golden, CO: National Renewable Energy Laboratory. NREL/TP-5C00-74840. <https://www.nrel.gov/docs/f20osti/74840.pdf>

Ramasamy, Vignesh, Zuboy, Jarrett, Woodhouse, Michael, O'Shaughnessy, Eric, Feldman, David, Desai, Jal, Walker, Andy, Margolis, Robert, and Basore, Paul. 2023. *U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks, With Minimum Sustainable Price Analysis: Q1 2023*. Golden, CO: National Renewable Energy Laboratory. NREL/TP-7440-87303. <https://www.nrel.gov/docs/f23osti/87303.pdf>

Green, A. E., and A. J. Bourne. *Reliability Technology*. New York: John Wiley and Sons, 1972

Klise, Geoffrey, Olga Lavrova, and Renee Gooding. *PV System Component Failure and Repair Data Compilation and Analysis*. SAND2018-1743. February 2018. <https://prodg.sandia.gov/techlib-noauth/access-control.cgi/2018/181743.pdf>. Mood, A.M., F. A.

NIST 2022 Energy Price Indices and Discount Factors for Life-Cycle Cost Analysis – 2022 Annual Supplement to NIST Handbook 135 Joshua D. Kneifel Priya Lavappa <https://doi.org/10.6028/NIST.IR.85-3273-37-upd1> May 2022

Word Occurrence in 522 O&M Work Orders (PVROM)

ENVIRONMENT	CAUSE OF DAMAGE	CONDITION	DETECTION OF FAILURE
Water	Recall	Ground Fault	Inspect
Snow	Install Error	Burn	Thermal/Infrared
Moisture	Broken Modules	Melt	UAS/UAV/Drone
Lightning	Mowing	Loose/Pulled	Aerial
Wind	Corrosion	Arc Fault	
Hurricane	Vegetation	Damage	
Hail	Animal	Fire	
	Dirt	Crimp	



Failed Connector (photo by Bruce King, Sandia National Laboratories)

Results:


- In the example of this 100 MW Utility-Scale PV system, the annual maintenance cost varies from year to year. There is an upward escalation of corrective maintenance costs caused by: 1) inflation increasing the cost of O&M; and 2) Weibull distributions showing increasing failure in later years. Every five years the cost of cleaning and inspection is visible.
- The "annualized" value (life cycle cost/year) is \$72k/year associated with connectors. Dividing by plant size gives \$0.72/kW/year additional O&M costs for connectors.
- A reserve account of \$187k would be arranged to quickly repair larger-than-average correctional maintenance costs (such as storm damage).
- Over the 25-year analysis period connectors represent almost \$1.5M in life cycle cost.

System Name	100 MW Utility-Scale PV
Results	
Annualized O&M Costs (\$/year)	\$1,774,563
Annualized Unit O&M Costs (\$/kW/year)	\$17.75
Maximum Reserve Account	\$5,299,351
Net Present Value O&M Costs (project life)	\$27,923,565
Net Present Value (project life) per Wp	\$0.279
NPV Annual O&M Cost per kWh	\$0.016



Component	Cost/Yr	NPV (life)	% of Total
AC wiring	\$9,859	\$25,332	1%
Insurance	\$497,500	\$7,051,658	23%
Asset Management	\$610,731	\$9,430,140	34%
Cleaning/Veget	\$253,380	\$3,987,082	14%
DC wiring	\$18,417	\$289,969	1%
Connector	\$105,507	\$1,628,724	6%
Documents	\$22,952	\$361,155	1%
Electrical	\$6,718	\$105,722	0%
Inverter	\$94,303	\$1,326,520	5%
Mechanical	\$92,986	\$1,463,177	5%
Meter	\$16	\$248	0%
Monitoring	\$51	\$957	0%
PV Array	\$118,116	\$1,868,609	7%
PV module	\$5,570	\$87,641	0%
Roof	\$0	\$0	0%
Tracker	\$0	\$0	0%
Transformer	\$448	\$7,050	0%
(blank)	\$0	\$0	0%
Total	\$1,774,563	\$27,923,565	100%

Connectors about 6% of O&M cost.



Value of Lost Production due to Connector failure exceeds maintenance costs of Connectors.

- In addition to the maintenance costs of connector, they contribute to downtime and lost production (kWh not generated due to connector failure).
- In dividing by reduced production, the per-kWh-delivered of \$0.0088/kWh includes the cost of maintenance and also the lost production of connector maintenance and underperformance and represents about 7% of the maintenance cost per kWh.

	Cost with Connectors	Cost without Connectors	Impact due to Connectors
Annualized O&M Costs (\$/year)	\$ 1,361,350	\$ 1,289,417	\$ 71,933
Annualized Unit O&M Costs (\$/kW/year)	\$ 13.61	\$ 12.89	\$ 0.72
Maximum Reserve Account	\$ 5,216,127	\$ 5,028,907	\$ 187,220
Net Present Value O&M Costs (project life)	\$ 28,274,335	\$ 26,780,331	\$ 1,494,004
Net Present Value (project life) per Wp	\$ 0.28274	\$ 0.26780	\$ 0.01494
NPV Annual O&M Cost per kWh	\$ 0.01259	\$ 0.01172	\$ 0.00088

Future Work:

- Collect More Failure Data
- Address Liability Risk
- Expand TEA analysis to include other PV system components
 - Other types of connectors (IDC)
 - Rapid Shutdown Devices
 - Eventually all components

