



# SCEP

STATE & COMMUNITY ENERGY PROGRAMS

## Options for meeting data center demand in Virginia

Focus on GETs and reconductoring

Quick turnaround technical support to the Virginia Department of Energy

U.S. Department of Energy State Energy Office Direct Technical Assistance (TA) Program

July 2024

Jarrad **Wright** [jarrad.wright@nrel.gov](mailto:jarrad.wright@nrel.gov)

Ram **Pandian** [RamMohan.Pandian@nrel.gov](mailto:RamMohan.Pandian@nrel.gov)







Background

# Growth in data centers in the US

- **Past**
  - Demand: 90 TWh (2020)
- **Present (2023)**
  - Number: ≈5381 data centers (~50% of world)
  - Demand: 160 TWh (~4% total U.S. demand)
  - Growth: ≈78% growth (2020-2023)
  - CAGR: ≈15.5% (2020-2023)
- **Future (2024-2030)**
  - Demand: 196 - 404 TWh
  - Growth: 22.5-152%
  - CAGR: 3.7-15%
  - % of U.S. demand: 4.6-9.1%



Number of data centers (by state); Source: [Data Center Map](#)



NOTES: CAGR – Compound Annual Growth Rate

Sources: [VEDP](#); [EPRJ](#); [Data Center Map](#)

# Growth in data centers in Virginia

- **Past**


- Demand:  $\approx 13$  TWh ( $\sim 1.7$  GW)

- **Present (2023)**

- Number:  $\approx 17\%$  of U.S. data centers (Loudoun county  $\approx 80\%$ )
  - Demand: 33.8 TWh ( $\geq 2.8$  GW)
  - Growth:  $\approx 115\%$  growth (2020-2023)
  - CAGR:  $\approx 29.1\%$  CAGR (2020-2023)
  - % of VA demand:  $\approx 25.6\%$  Virginia electrical demand

- **Future (2024-2030, EPRI)**



- Demand (EPRI): 43.7 - 89.9 TWh
  - Demand (DOM): 47.3 TWh (2023), 114 TWh (2024)
  - Growth: 29.3-166% growth
  - CAGR: 3.7-15%
  - % of VA demand: 29.3-46.0%



STATE	2023 Load		Low-growth scenario (3.71%)		Moderate-growth scenario (5%)		High-growth scenario (10%)		Higher-growth scenario (15%)	
	MWh/y	% of Total State Electricity Consumed (%EC)	MWh/y	% of Total State Electricity Consumed (%EC)	MWh/y	% of Total State Electricity Consumed (%EC)	MWh/y	% of Total State Electricity Consumed (%EC)	MWh/y	% of Total State Electricity Consumed (%EC)
Virginia	33,851,122	25.59%	43,683,508	29.28%	47,631,928	31.10%	65,966,260	38.47%	89,880,357	46.00%

Sources: [VEDP](#); [EPRI](#)

# PJM Dominion Load Forecast




1. **Little growth** projected 4 years ago (2019 PJM forecasts)
2. **Large changes since 2022** and **uptick in 2023** PJM forecasts (notably higher in 2024)
3. Almost all growth is **data center growth** ( $\approx 300\%$  data center growth between 2023-2030 expected, 21.8% CAGR)
4. Data centers could compose **half of Virginia** electrical energy demand by 2030

NOTE: DOM – Dominion; Data center energy demand estimated based on typical load factor  
 Sources: NREL (generated based on [PJM load forecast data](#))



# Data center demand characterization

- **Small-scale** data centers. 0.5-2.0 MW each (~10% of data center demand)
- **Large-scale** commercial data centers
  - Enterprise data centers (20-30% of data center demand)
  - Co-location and Hyperscale data centers (60-70% data center demand)
- **Recently** - efficiency gains being outstripped by growing compute demand (especially co-located and hyperscale data centers)

U.S. data center historical trend (2000-2023)



Average annual PUE in data centers (2007-2023)



Data center electrical distribution system block diagram


LV/MV Low-voltage / medium-voltage  
 UPS Uninterrupted Power Supply  
 PDU Power Distribution Unit  
 RPP Remote Power Panel



Current planning for growth

# Dominion (Virginia) T&D Networks

- **PJM transmission (Virginia)**
  - Mostly 500 kV
  - Some 345 kV and 765 kV
- **Transmission (DOM)**
  - 6800 miles
  - 69 – 500 kV
- **Distribution (DOM)**
  - 54 000 miles
  - 400 substations
  - 4 - 46 kV



Sources: [PJM RTEP 2023](#); [Dominion IRP 2023](#)



# Dominion (Virginia) IRP 2023 expansion plans (5 options) requires substantial transmission investment

- **Current plans** in the [Dominion Virginia IRP 2023](#) aligned with Virginia 100% clean by 2045 (Plan D and Plan E) relative to other plans (Plan A, Plan B and Plan C)
    - *"... severely challenge the ability of the transmission system to meet customers' reliability expectations"*
    - *"... would require an investment level that exceeds current transmission level expenditures and would likely exceed the future transmission level costs initially identified in the 2023 Plan"*
- NOTE: Further details not available in the public domain at this stage
- Current plans expand mostly 115 kV and 230 kV (some 500 kV) - further analysis forthcoming from Dominion in Virginia

(\$B)	Plan A	Plan B	Plan C	Plan D	Plan E
Total System Costs	\$88.5	\$100.2	\$99.7	\$108.8	\$105.8
Grid Transformation Plan (Net of Benefits)	\$(1.6)	\$(1.6)	\$(1.6)	\$(1.6)	\$(1.6)
Strategic Underground Program	\$0.7	\$0.7	\$0.7	\$0.7	\$0.7
Transmission	\$22.2	\$28.4	\$28.4	\$33.1	\$33.1
<b>Total Plan NPV</b>	<b>\$109.7</b>	<b>\$127.7</b>	<b>\$127.2</b>	<b>\$140.9</b>	<b>\$138.0</b>
Plan Delta vs. Plan A	\$ -	\$ 18.0	\$17.5	\$31.2	\$ 28.3


Notes: As previously ordered by the SCC, this figure includes incremental cost estimates associated with transmission and distribution investments. All costs are estimates and will vary based on the actual generation, transmission, and distribution infrastructure developed to meet customer needs. (1) Total system costs include the results from Figures 2.2.1 through 2.2.5; approved, proposed, future, and generic DSM, as applicable; costs related to environmental laws and regulations; renewable energy integration costs; and REC banking as discussed in Section 4.7.4, **REC-Related Assumptions**. (2) All NPVs are calculated with a 6.52% discount rate. (3) Numbers may not add due to rounding.

	Plan A	Plan B	Plan C	Plan D	Plan E
<b>NPV Total (\$B)</b>	\$109.70	\$127.70	\$127.20	\$140.90	\$138.00
<b>Approximate CO<sub>2</sub> Emissions from Company in 2048 (Metric Tons)</b>	43.8 M	35.9 M	36 M	0 M	0 M
<b>Solar (MW)</b>	10,800 15-yr 19,800 25-yr	10,875 15-yr 19,875 25-yr	10,800 15-yr 19,800 25-yr	10,875 15-yr 23,955 25-yr	11,094 15-yr 24,294 25-yr
<b>Wind (MW)</b>	3,040 15-yr 3,220 25-yr	3,040 15-yr 3,220 25-yr	3,040 15-yr 3,220 25-yr	3,040 15-yr 3,220 25-yr	3,040 15-yr 3,220 25-yr
<b>Storage (MW)</b>	1,050 15-yr 3,960 25-yr	2,370 15-yr 5,190 25-yr	2,220 15-yr 5,220 25-yr	2,370 15-yr 9,780 25-yr	2,910 15-yr 10,350 25-yr
<b>Nuclear (MW)</b>	-- 15-yr -- 25-yr	804 15-yr 1,608 25-yr	804 15-yr 1,608 25-yr	1,608 15-yr 4,824 25-yr	1,072 15-yr 4,288 25-yr
<b>Natural Gas Fired (MW)</b>	5,905 15-yr 9,300 25-yr	2,910 15-yr 2,910 25-yr	2,910 15-yr 2,910 25-yr	970 15-yr 970 25-yr	970 15-yr 970 25-yr
<b>Retirements (MW)</b>	-- 15-yr -- 25-yr	-- 15-yr -- 25-yr	-- 15-yr -- 25-yr	-- 15-yr 11,399 25-yr	-- 15-yr 11,399 25-yr

Sources: [Dominion IRP 2023](#)

# PJM RTEP 2023 concentrated transmission expansion in Loudoun County

PJM RTEP 2023 Baseline projects (Dec. 2023)





Sources: [PJM RTEP 2023](#)

# PJM RTEP 2023 on transmission expansion and Loudoun County growth specifically

- **Many Baseline expansions in RTEP 2023**
  - Most at 115 kV and 230 kV
  - Some at 500 kV
- **More specifically**, PJM continues to address "Data Center Alley" (Loudoun County, VA) demand growth
- But **growth is now higher** in 2024 forecasts than expected in RTEP 2023 (as seen in 2024 demand forecasts)
- PJM further soliciting **transmission expansion solutions** to meet this growth (amongst other areas)

Sources: [PJM RTEP 2023](#)

Northern Virginia RTEP 2023 Baseline projects (Dec. 2023)



Graphic by NREL  
 (based on [PJM RTEP 2023](#))



Summary of options  
GETs and Reconductoring

# Summary of potential interventions

	GETs (DLR)	GETs (TTO)	GETs (APFC)	Reconductoring
<b>Description</b>	Dynamic Line Rating (DLR) enables increased thermal rating based on real-time temp/wind conditions	Transmission Topology optimization (TTO) are software based operational interventions that adjust power-flow to avoid congestion (re-route power-flow) <sup>1</sup>	Typically, power electronics based (FACTS) that are located at substations to control power flow (+address reliability), similar role to PSTs/PARs	Increases thermal rating by replacing conductors with advanced conductors (higher ampacity ratings)
<b>Technical impact</b>	High; 10-40% increased thermal rating	Medium; Effective congestion management (reducing binding operating periods)	Medium; Improved distribution of power flow in radial/meshed networks (potential transfer capability improvement 10-25%)	Highest; 50-100% increased thermal rating (effective on short-distance lines)
<b>Cost / value</b>	Low / Med	Low / Med	Med / Med	Med / High
<b>Timeline (total)</b>	3-12 months	<6 months	6-18 months	12-36 months
<b>Regulatory/permitting</b>	●	●	●	●
<b>Design</b>	●	●	●	●
<b>Construction</b>	●	●	●	●

**Relative timeline (qualitative)**



<sup>1</sup> Assuming the switching hardware is already in place (almost always the case);

APFC – Advanced Power Flow Controller; FACTS – Flexible AC Transmission Technologies; PAR – Phase Angle Regulator; PST – Phase-Shifting Transformer


# GETs and Reconductoring

GETs: DLR

# GETs (DLR)

- **Dynamic Line Rating (DLR)** is a dynamic transmission line rating based on local conditions or estimates thereof (temperature, wind speed/direction, solar irradiance)
- DLR is the most advanced manner for transmission line ratings to be established and used. Others include:
  - Static Line Rating (SLR) - default
  - Seasonally Adjusted Rating (SAR)
  - Ambient Adjusted Rating (AAR)
- DLR can provide for additional ampacity of a transmission line
- In principle, DLR uses the same heat-balance equations as SLR but includes more-sophisticated time-varying approaches based on real-time data or forecasts.
- Where AAR uses temperature-only, DLR also uses temperature, wind speed/direction and solar irradiance
- Field data collected along with engineering design criteria is used to calculate the maximum allowable conductor current.

## Types of line capacity rating




Source: [B. Berry \(2023\) ESIG Fall Workshop](#)

**FERC Order 881** mandates transmission service providers, transmission owners, and ISOs/RTOs to establish and implement AAR for all transmission lines (at least hourly).

**Compliance Deadline:** July 12, 2025


# Most ISOs/RTOs use Static Line Ratings (SLRs) or Seasonally Adjusted Ratings (SARs)



Sources: [DoE, Next-Generation Grid Technologies](#)



# GETs (DLR)



Note: Thermal current limit is the maximum current permitted to ensure no conductor material is damage and no maximum line sag is exceeded.

## PHYSICAL AND ELECTRICAL FACTORS


- Line current
- Sag/tension
- Physical and electrical properties of the material and construction of the conductor
- Insulation

## WEATHER FACTORS

- Wind speed
- Wind direction
- Solar radiation
- Ambient temperature



## Demonstration of DLR, AAR and SLR for a 345 kV line



DLR is in blue, AAR is in brown, and static ratings are in black.

- DLR
- AAR
- Static ratings

Sources: [Lessons from first deployment of Dynamic Line Ratings: AES Corporation \(2024\)](#)

Sources: [Dynamic Line Rating - Innovation Landscape Brief, IRENA](#)

## DLR Tools

### Direct Conductor Monitoring

Clearance

Tension

Temperature

Sag

### Environmental Parameter Monitoring

Numerical  
& Statistical  
Methods

Direct-  
Measured

Physics  
Model with  
Direct-  
Measured

Conductor  
Replica

Sources: Based on [DOE \(2019\) – Dynamic Line Rating](#)

# GETs (DLR) – Barriers

Data Accuracy &  
Reliability

Volatile ratings  
complicate dispatch

Complex process to  
share dynamic  
ratings within ISOs

Accelerated  
equipment aging

Increased utility  
investments

Familiarity with the  
technology

Cyber-security risk

Lack of broadly  
shared technical  
results from pilot  
projects

# GETs (DLR) – Case Studies

## Oncor Electric Delivery Company/ERCOT

- **Year:** 2014
- **Capacity Increase:** 345 kV lines - 6-14%(above AAR); 138 kV lines – 8-12%(above AAR)

## AEP

- **Year:** 2018
- **Capacity increase:** Unknown

## INL/NOAA/Altalink/Idaho Power Company

- **Year:** 2019
- **Capacity Increase:** 72% (specific regions with sufficient winds)

## EPRI/TVA

- **Year:** 2020
- **Capacity increase:** Unknown

## National Grid

- **Year:** 2021
- **Capacity increase:** 13%

## ORNL/Xcel Energy

- **Year:** 2021
- **Capacity Increase:** 9-33%(Winter), 26-36%(Summer)

## PPL

- **Year:** 2021
- **Capacity increase:** 25-29%

## AES Corporation

- **Year:** 2023-2024
- **Capacity increase:**
  - 345 kV: 27% (Summer), 81% (Winter)
  - 138 kV: 19% (Summer), 55% (Winter)
  - 69 kV: 23% (Summer), 9% (Winter)



Sources: Lessons from first deployment of Dynamic Line Ratings: AES Corporation – April 2024

Sources: [INL \(2022\), A Guide to Case Studies of Grid Enhancing Technologies](#)

## DoE Grid Resilience & Innovation Partnerships (GRIP) Program:

- Total DOE funding: \$3.5 billion
- Total projects: 58 across 44 states

## Analytics & Control for Driving Capital Efficiency Project:

- This project with Dominion: \$67.3 million
- Grid capacity and renewable integration
- Nine (9) specific outcomes and expected benefits
- One of these: **“The world's Largest dynamic line rating project”**
- **Intended to address 200-500% load growth on specific transmission circuits in under 3 years**
- **Further coordination with Dominion (Virginia) to get status & further details (specifically – DLR components)**

Sources: [DoE GDO](#)



### FACT SHEET

## GRID RESILIENCE AND INNOVATION PARTNERSHIPS PROGRAM

Established by the Bipartisan Infrastructure Law, the U.S. Department of Energy's Grid Deployment Office is administering a historic \$10.5 billion investment via the Grid Resilience and Innovation Partnerships (GRIP) program to enhance grid flexibility, improve the resilience of the power system against growing threats of extreme weather and climate change, and ensure American communities have access to affordable, reliable, clean electricity when and where they need it.

## MODERNIZING INFRASTRUCTURE TO SUPPORT GRID MANAGEMENT AND DECARBONIZATION

As clean and distributed energy resources (DERs) are deployed, grid operators will need new tools for planning, managing, and controlling them. The Analytics and Control for Driving Capital Efficiency (ACDC) project will expand the critical grid management capabilities needed to responsibly and effectively steward the energy transition. By boosting Dominion Energy Virginia's DER management capabilities, this project will increase control and improve strategic asset planning and deployment through more coordinated interconnection.

### Anticipated Outcomes and Benefits

Dominion Energy Virginia anticipates a substantial investment in decarbonization infrastructure, including an approximately \$10 billion investment in offshore wind. This project will adapt infrastructure to interact with technology and customers at the grid edge, enabling real-time grid visualization and advanced grid management while ensuring a variety of community benefits, including:

- › Dynamic performance monitoring will reduce approximately 500 outages per year across the grid, including in disadvantaged communities (DACs), and enable up to \$70 million of clean generation to reach the grid that would otherwise be curtailed and replaced with more costly generation.
- › Deploying the world's largest dynamic line ratings project to allow Dominion Energy Virginia's operators to more effectively manage some of the growing transmission capacity constraints in PJM's service territory (which has seen a 200% to 500% load increase on certain circuits in less than three years).
- › Deploying an open-source grid-forming inverter and a 2 to 4 MW BESS (Battery Energy Storage System) for a rural community. These deployments will lay the groundwork for similar projects across the utility's service territory as well as provide insights for the PJM and Federal Energy Regulatory Commission rulemaking processes.
- › Improving grid planning by collecting real-time electrical grid data.
- › Increasing network capacity to account for substantial increases in electric loads.
- › Controlling and preparing for voltage and frequency fluctuations caused by renewable energy resources being added to the electrical grid.
- › Deploying devices and control capabilities to the remaining three-phase 34.5 kV distribution network, enabling the integration of renewable energy sources at rural customer sites in Virginia and North Carolina while equipping operators with intelligent grid devices.
- › Engaging communities in the earliest stages of project development, including DACs, environmental justice communities, tribal governments, local municipalities, and local residents.
- › Committing to work with academic institutions to increase the clean energy jobs pipeline and provide job training for individuals, including a deeper focus on military talent.

### PROJECT DETAILS

- › **Project:** Analytics and Control for Driving Capital Efficiency Project
- › **Applicant/Selector:** Virginia Electric and Power Co. (Dominion Energy Virginia)
- › **GRIP Program:** Smart Grid Grants (Bipartisan Infrastructure Law, Section 40107)
- › **Federal cost share:** \$33,654,095
- › **Recipient cost share:** \$33,654,095
- › **Project Location:** Virginia and North Carolina
- › **Project type:** Grid Capacity and Renewables Integration

### HELPFUL LINKS


- › [Grid Resilience and Innovation Partnerships Program](#)
- › [About the Grid Deployment Office](#)

# GETs and Reconductoring

GETs: Transmission Topology Optimization (TTO)

# GETs (TTO)

- **Transmission Topology optimization (TTO)** implements software that finds optimized reconfigurations of the network topology to reroute power around congestion (analogy – *"Waze for the transmission grid"*)
- The alternative being classical congestion management (network topology fixed and generation redispatched)
- Ensuring reliable reconfiguration is core to TO operations e.g. contingency performance, transient/voltage stability
- Typically implemented by System Operator
- Typically <1 year for implementation



Sources: [J. Selker \(2023 ESIG Fall Workshop\)](#)





# GETs (TTO) - Barriers

Unfamiliarity with the technology

Lower returns with less capital investments

Integration with existing operations and tools

Market rules (congestion management - redispatch)

Classically only applied seasonally or in emergency conditions (SPS/RPS schemes)

Computational complexity at scale (magnified at real-time)

Impacts on transmission elements (switching operations)

System impacts (switching disturbances, cascading failures)

# GETs (TTO) – Case Studies

PJM

- Year: 2014
- Impact: Simulated TO reduced RT congestion costs by 50%

MISO


- Year: 2021
- Impact: Increased throughput by 25-60% at known 161 kV constraints (at known market seams)

Alliant

- Year: 2021
- Impact: Pilot demonstrated potential cost savings of 39%


Utility (in SPP)

- Year: 2023
- Impact: Pilot estimates potential for 85% reduction in congestion costs (with consistent use of TO)



Reconfiguration impact across Alliant (pilot)

Sources: NewGrid



Reconfiguration impact of a known 161 kV constraint in MISO

Sources: Potomac Economics


Sources: [P. Ruiz \(2023\) ESIG Fall Workshop](#); [DoE \(2020\) Advance Transmission Technologies](#)

# GETs and Reconductoring

GETs: Advanced Powerflow Control (APFC)


# GETs (APFC)

- **Advanced Power Flow Controllers (APFCs)** are hardware devices that enable the shifting of power-flow in parallel or meshed networks by adjusting the effective reactance of the network
- APFCs are **more compact**, can be **faster in response** and **more efficient** than Phase-Shifting Transformers (PSTs) / Phase-Angle Regulators (PARs)
- Typically located at existing substations
- Ability to reduce regional RE curtailment, reduce congestion (100s of hours per year) and/or improve overall transfer capability (10-25%), defer transmission investment
- Typically <1 year for construction (1-2 years for implementation)



Sources: [J. Selker \(2023 ESIG Fall Workshop\)](#)

# GETs (APFC) - Barriers



# GETs (APFCs) – Case Studies

AEP

- **Year:** 1998
- **Impact:** Added 770 MW of capacity (reduced power losses)

NGET (UK)

- **Year:** 2019
- **Impact:** Resolve network congestion at 275 kV and 400 kV (3 substations, 2 GW of RE unlocked)

Central Hudson  
(US)

- **Year:** 2020
- **Impact:** Capacity increase at 345 kV (185 MW)

TransGrid (Aus)

- **Year:** 2022
- **Impact:** Increased transfer capability of 170 MW at 330 kV (2 circuits)

ISA Transelca  
(Colombia)

- **Year:** 2023
- **Impact:** Unlock 200 MW and resolve congestion at 220 kV for RE integration



SSSC APFC (3 substations) (UK)

Sources: SmartWires


Sources: [SmartWires \(various case studies\)](#); [DoE \(2020\) Advance Transmission Technologies](#)

# GETs and Reconductoring

Reconductoring

# Reconductoring

- **Reconductoring** involves upgrading the existing transmission system's transfer capacity by reconductoring selected network lines with conductors capable of transmitting greater electrical capacity.
- **Almost always cost-effective** compared to new-build if feasibility constraints are met
- Can enable up to **double** the line capacity within an existing ROW **with advanced reconductoring** (ACCR, ACCS, ACCC, AECC)
- Helps provide **near-term interregional capacity**, providing time for new lines to be developed for long-term needs
- Distributes new transmission capacity over more transmission corridors/interfaces




Advanced conductor renderings courtesy of Idaho National Laboratory.<sup>8</sup>

	Name	Summary description	Provider
Advanced conductors (composite core)	ACCR – Aluminium Conductor Composite Reinforced	• Multi-strand Al core with Al-zirconium outer strands	3M
	ACCS - Aluminium Conductor Composite Supported (a.k.a. C <sup>2</sup> )	• Multi-strand carbon core and trapezoidal Al outer-strands	SouthWire
	ACCC – Aluminium Conductor Composite Core	• Composite carbon & glass fiber core with annealed Al or Al-zirconium outer strands	CTC Global
	AECC – Aluminium Encapsulated Carbon Core (a.k.a. TS)	• Carbon-core (mono) with Al sheath and annealed AL trapezoidal outer strands	TS Conductor

Sources: [GridLab \(2023\), 2035 Reconductoring Technical Report](#); [GridLab \(2024\) Supporting Advanced Conductor Deployment: Barriers and Policy Solutions Companion Report](#); [EPRI Fact sheet: Advanced Conductors](#)



# Reconductoring – Barriers



# Reconductoring – Successful Deployments

## Lower Rio Grande Valley Reconductoring Project

- **Location:** Texas, United States
- **Re-Conductor:** ACCC
- **Voltage:** 345 kV
- **Project status:** Completed (+100% capacity increase)

## Big Creek 230kV Corridor

- **Location:** Southern California, United States
- **Re-Conductor:** ACCC
- **Voltage:** 230 kV
- **Project status:** Completed

## 380 kV Reconductoring (Belgium)

- **Location:** Belgium
- **Re-conductor:** ACCC
- **Voltage:** 380 kV
- **Project status:** On-going (+100-150% capacity increase)

## TenneT Beter Benutten Bestaande 380 kV Project

- **Location:** Netherlands
- **Re-conductor:** HTLS
- **Voltage:** 380 kV
- **Project status:** On-going (+60% capacity increase)

Sources: [GridLab \(2023\)](#), [2035 Reconductoring Technical Report](#)

## Hot-line reconductoring with temporary support poles















## Lower Rio Grande Valley Reconductoring Project

Sources: IEEE PES ESMO Conference Presentation, Glueck 2016

## Conclusions and potential next steps

# Summary of potential interventions

	GETs (DLR)	GETs (TTO)	GETs (APFC)	Reconductoring
<b>Description</b>	Dynamic Line Rating (DLR) enables increased thermal rating based on real-time temp/wind conditions	Transmission Topology optimization (TTO) are software based operational interventions that adjust power-flow to avoid congestion (re-route power-flow) <sup>1</sup>	Typically, power electronics based (FACTS) that are located at substations to control power flow (+address reliability), similar role to PSTs/PARs	Increases thermal rating by replacing conductors with advanced conductors (higher ampacity ratings)
<b>Technical impact</b>	High; 10-40% increased thermal rating	Medium; Effective congestion management (reducing binding operating periods)	Medium; Improved distribution of power flow in radial/meshed networks (potential transfer capability improvement 10-25%)	Highest; 50-100% increased thermal rating (effective on short-distance lines)
<b>Cost / value</b>	Low / Med	Low / Med	Med / Med	Med / High
<b>Timeline (total)</b>	3-12 months	<6 months	6-18 months	12-36 months
<b>Regulatory/permitting</b>				
<b>Design</b>				
<b>Construction</b>				

**Relative timeline (qualitative)**




<sup>1</sup> Assuming the switching hardware is already in place (almost always the case);


APFC – Advanced Power Flow Controller; FACTs – Flexible AC Transmission Technologies; PAR – Phase Angle Regulator; PST – Phase-Shifting Transformer

# Conclusions

- **Data center demand growth** in Virginia will need to be met with many options – GETs and/or reconductoring have the potential to be part of the solution suite in the short-term and medium-term
- **Almost all GETs and reconductoring technologies have more favorable economics** than transmission wires investments considering relatively **low levels of existing wide-scale deployment**
- Deployment of GETs and/or reconductoring is **not a one size fits all** – requires detailed analysis (rigorous technical assessments in reliability models and associated cost-benefit analysis)
- **Complementary nature** of GETs and/or reconductoring impacts have the potential to be **synergistic** when implemented together (more congestion relief, more transfer capability, more cost savings)



DLR is in blue, AAR is in brown, and static ratings are in black.  
 Sources: Lessons from first deployment of Dynamic Line Ratings: AES Corporation – April 2024



Sources: J. Selker (2023 ESIG Fall Workshop)

# Potential next steps

- In addition to GETs and reconductoring, **consider the timing of all interventions and ordering by the most impactful** based on pre-defined criteria
  - Consider a complete taxonomy of options (in addition to GETs and/or reconductoring)
    - Demand-side management (DSM)
    - Expanded local supply options (augmented back-up power)
    - Generation expansion (within and beyond the Dominion and PJM territory)
    - Transmission expansion (localized strengthening and interregional expansion)
  - Pre-defined criteria:
    - Scale of technical impact
    - Value/cost
    - Time for implementation
- **Establish the responsible stakeholder** best positioned to address barriers e.g. regulator (State/Federal), utility, transmission owner, RTO, customer
- **Address barriers** in order of priority (considering broader scope than GETs and/or reconductoring)
- **Disseminate operational know-how** and learnings widely from pilots and commercial implementations of GETs and reconductoring

# Thank you

NREL/PR-6A40-90734

July 2024

Jarrad **Wright** [jarrad.wright@nrel.gov](mailto:jarrad.wright@nrel.gov)

Ram **Pandian** [RamMohan.Pandian@nrel.gov](mailto:RamMohan.Pandian@nrel.gov)

This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of State and Community Energy Programs. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

