

Hourly dynamic line ratings for existing transmission across the contiguous United States (preliminary results)

Patrick R. Brown, Kodi Obika, Sophie Bredenkamp, Le (Helen) Lu

October 2024

A component of the NREL "Advanced Transmission Modeling" project funded by GDO and jointly managed by GDO and WETO (DOE)

Study context

Many studies have demonstrated the value of dynamic line ratings (DLR):

- INL 2022 A Guide to Case Studies of Grid Enhancing Technologies
- DOE 2022 Grid-Enhancing Technologies: A Case Study on Ratepayer Impact
- DOE 2019 Dynamic Line Rating
- Bhattarai et al. 2018 Improvement of
 Transmission Line Ampacity Utilization by Weather-Based Dynamic Line Rating
- Karimi et al. 2018 Dynamic thermal rating of transmission lines: A review
- Fernandez et al. 2016 Review of dynamic line rating systems for wind power integration

• ...


Many of these studies cover small collections of transmission lines or limited geographic regions.

But there are tens of thousands of transmission lines spread across the contiguous U.S., and quantitative findings for particular transmission lines or regions might not provide an accurate estimate of DLR benefits across the U.S. as a whole.

Here, we:

- Estimate hourly DLRs for ≥50,000 high-voltage transmission lines across the contiguous U.S. using publicly available line routes and historical weather for 2007–2013
- Compare ratings using different combinations of hourly weather data (air temperature, solar irradiance, and wind speed/direction)

Overview: Estimating dynamic line ratings (DLR) using historical weather



https://nsrdb.nrel.gov/

https://www.nrel.gov/grid/wind-toolkit.html

Study scope: Estimating DLRs using historical weather

What does this study **do**?

- Historical assessment using 2007– 2013 weather from WTK/NSRDB
- Calculate ratings consistent with a steady-state conductor design temperature using IEEE 738-2012
- Assume ACSR conductor parameters, with a single representative conductor type per voltage level
- Assess the impact of different line rating methods on hourly ratings

What does this study **NOT** do?

- Assess forecastability
- Account for climate change impacts
- Model line sag and clearance for individual spans
- Account for wildfire risk or icing/wind loads
- Consider emergency ratings
- Account for the actual conductor type installed on each line (which is not public information)
- Assess ratings of transformers / breakers / etc
- Assess the cost of implementing different rating methods
- Assess the economic/social benefits (congestion reduction, production cost savings, emissions mitigation) of different rating methods

Methodology: Line ratings (IEEE 738 and CIGRE 207)

Convective cooling (IEEE)

$$\begin{split} q_c &= \max \left(q_c^{zero}, q_c^{low}, q_c^{high}\right) \\ q_c^{zero} &= 3.645 \cdot \rho_{air}^{1/2} \cdot D^{3/4} \cdot \left(T_{conductor} - \boldsymbol{T_{air}}\right)^{5/4} \\ q_c^{low} &= K \cdot \left(1.01 + 1.35 \cdot N_{Re}^{0.52}\right) \cdot k_{air} \cdot \left(T_{conductor} - \boldsymbol{T_{air}}\right) \\ q_c^{high} &= K \cdot 0.754 \cdot N_{Re}^{0.6} \cdot k_{air} \cdot \left(T_{conductor} - \boldsymbol{T_{air}}\right) \\ N_{Re} &= \frac{D \cdot \rho_{air} \cdot \boldsymbol{v_{wind}}}{\mu_{air}} \\ K &= 1.194 - \cos(\boldsymbol{\phi}) + 0.194 \cos(2\boldsymbol{\phi}) + 0.368 \sin(2\boldsymbol{\phi}) \\ \rho_{air} &= \frac{\boldsymbol{P_{air}}}{N_A k_B \boldsymbol{T_{air}}} \end{split}$$

https://doi.org/10.1109/IEEESTD.2013.6692858

https://www.e-cigre.org/publications/detail/207-thermal-behaviour-of-overhead-conductors.html

Physical parameters

$$k_{air}$$
 = thermal conductivity of air
 μ_{air} = dynamic viscosity of air
 N_{Re} = Reynolds number
 N_A = Avogadro's number
 k_B = Boltzmann constant

Conductor parameters

R = resistance D = diameter α = absorptivity (0.8) ε = emissivity (0.8) $T_{conductor}$ = max temperature (75°C)

Radiating cooling (IEEE)

$$q_r = \pi \cdot D \cdot k_B \cdot \left(T_{conductor}^4 - T_{air}^4 \right)$$

Solar heating (CIGRE)

$$q_s = \alpha \cdot D \cdot \mathbf{GHI}$$

Ampacity


$$q_{resistive} = I^{2}R = q_{c} + q_{r} - q_{s}$$

$$I = \sqrt{\frac{q_{c} + q_{r} - q_{s}}{R}}$$


Hourly weather parameters

 T_{air} = air temperature (10m, WTK) v_{wind} = wind speed (10m, WTK) ϕ = angle between wind and conductor headings (10m, WTK) P_{air} = air pressure (0m, WTK) GHI = global horizontal irradiance (NSRDB)


Literature review: Static & seasonal line rating parameters



Sensitivity analysis: Weather parameters



Sensitivity analysis: Conductor parameters



Validation against industry conductor datasheets

Industry conductor datasheets providing:

- Conductor diameter
- Resistance at 75°C
- Ampacity under specified conductor temperature, conductor emissivity and absorptivity, ambient air temperature, irradiance, and wind speed

https://www.southwire.com/wire-cable/bare-aluminum-overhead-transmission-distribution/acsr/p/ALBARE6

Our assumed conductor type:


(Bartos et al. 2016)


69 kV: Linnet

115 kV: Condor


230 kV: Martin

• 345+ kV: Cardinal






Methodology: Spatial resolution



Methodology: Spatial resolution

HIFLD line 202132


Hourly weather parameters for each NSRDB and WTK grid cell intersected by the transmission line (here shown for a single 24-hour day for a single line) are used to calculate the hourly line rating



Caveats and Limitations

- 1. Results are sensitive to the weather data used; if 2007–2013 windspeed in the WIND Toolkit is biased high (for example), the calculated DLR will be biased high as well
 - 1. Validation studies on the WIND Toolkit and NSRDB are available at:
 - King, J. et al. "Validation of Power Output for the WIND Toolkit", 2014 (NREL/TP-5D00-61714)
 - Draxl, C. et al. "Overview and Meteorological Validation of the Wind Integration National Dataset Toolkit", 2015 (NREL/TP-5000-61740)
 - Sengupta, M. et al. "Validation of the National Solar Radiation Database (NSRDB) (2005–2012)", 2015 (NREL/CP-5D00-64981)
 - Habte, A. et al. "Evaluation of the National Solar Radiation Database (NSRDB Version 2): 1998–2015", 2017 (NREL/TP-5D00-67722)
 - 2. Future work could explore other weather datasets and more recent weather years
 - 3. More work is required to determine how well ratings calculated from NSRDB and WIND Toolkit data reflect the actual ratings observed by installed sensors (such as sag or tension monitors); in general, ratings calculated from modeled weather data are not a substitute for direct sensor data
- 2. Assuming a single representative conductor type (ACSR of a single diameter) for each voltage level is an important simplification; reported line ratings at a given voltage level can vary widely
 - 1. Focusing on the relative change between rating methods (rather than absolute ampacities) partially mitigates this limitation
- 3. HIFLD line routes are primarily based on imagery instead of exact construction data and may have errors
- 4. We use historical weather data directly; calculated line ratings are thus more indicative of real-time ratings than forecasted ratings
 - 1. Future work could explore the use of forecast error margins to estimate weather-adjusted ratings under realistically forecastable conditions

Dynamic line ratings: One-hour snapshot



Line rating frameworks explored here


Rating system (definitions used in this study; not necessarily standard)	Abbrev	Ambient temperature	Solar irradiance	Windspeed †		
Static line ratings	SLR	40°C	1000 W/m ²	0.61 m/s		
Seasonal line ratings	ZLR	Industry data	1000 W/m ²	0.61 m/s	Current practice	
Ambient-adjusted line ratings	ALR	Hourly	1000 W/m ²	*		
Nighttime-adjusted line ratings	NLR	Hourly	[0,1000] W/m ²	*	← Required by FERC Order 881	
Clear-sky-adjusted line ratings	CLR	Hourly	Hourly clear-sky	*		
Irradiance-adjusted line ratings	ILR	Hourly	Hourly	*	Proposed in FERC ANOPR	
Dynamic line ratings	DLR	Hourly	Hourly	Hourly	on 2024-06-27	

^{*} Not directly specified; here, we compare static windspeed assumptions of 0.61 m/s (default) and 0 m/s

- 1. What are the benefits of clear-sky-adjusted ratings (CLR) over the nighttime-adjusted ratings (NLR) required by FERC Order 881?
- 2. What are the benefits of measured-irradiance-adjusted ratings (ILR) over CLR?
- 3. What are the benefits of full dynamic line ratings (DLR, including windspeed) over ILR?
- 4. Do heuristics based on average wind conditions effectively predict the benefits of DLR?


[†] In the results shown here, only DLR uses location-specific hourly air pressure; all other rating methods use 1 standard atmosphere






Rating system	Abbrev	Ambient temperature	Solar irradiance	Windspeed
Static line ratings	SLR	40°C	1000 W/m ²	0.61 m/s


























HIFLD line







How do different ratings compare? (marginal change)



How do different ratings compare? (total change)




How does clear-sky compare to day/night?



For **50%** of lines, the clear-sky rating is...

- **7**% higher than the day/night rating in **20**% of hours
- **10**% higher in **10**% of hours
- **11%** higher in **5%** of hours


How does actual irradiance compare to clear-sky?



For **50%** of lines, the actual-irradiance rating is...

- 1% higher than the clear-sky rating in 20% of hours
- **2**% higher in **10**% of hours
- 4% higher in 5% of hours

What changes when actual windspeed is used?



For **50%** of lines, the full dynamic (including windspeed) rating is...

- 7% lower than the actual-irradiance rating in 20% of hours
- 8% higher in **50**% of hours
- **26**% higher in **20**% of hours

Line heading N/S

"Overrated" hours are sensitive to windspeed assumptions


Explore two short artificial lines; one heading N/S, one heading E/W:




In this location, the prevailing wind direction is N/S:

Preliminary


results



- 1 hour (0.002%) from 2007–2013 meets SLR conditions, where:
 - Temperature ≥ 40°C
 - GHI \geq 1000 W/m²
 - Wind speed ≤ 0.61 m/s (ignoring direction)
- 4,511 hours (7.4%) where windspeed ≤ 0.61 m/s



Line heading E/W





results in many "overrated" hours

"Overrated" hours are sensitive to windspeed assumptions


Preliminary results

For each rating method, in how many hours is the rating ≥1% greater than the actual rating (taking DLR as the actual rating)?







Zero windspeed for ALR, NLR, CLR, ILR:




What if we assume zero windspeed for ALR, NLR, CLR, ILR? (marginal change)



What if we assume zero windspeed for ALR, NLR, CLR, ILR? (total change)




What if we assume zero windspeed for ALR, NLR, CLR, ILR? (marginal change)



For 50% of lines, the ambient (temperature-adjusted) rating is...

- 4% lower than the static rating in 20% of hours
- **9**% higher in **50**% of hours
- **21**% higher in **20**% of hours

What if we assume zero windspeed for ALR, NLR, CLR, ILR? (marginal change)




For 50% of lines, the full dynamic (including windspeed) rating is...

- 14% higher than the actual-irradiance rating in 80% of hours
- **35**% higher in **50**% of hours
- **57**% higher in **20**% of hours

Exploring an average-windspeed threshold

Combine with HIFLD routes and quantify the fraction of each line above a given average windspeed




Preliminary results


Preliminary

results

Exploring an average-windspeed threshold




Exploring an average-windspeed threshold




Some observations

1. Hourly line ratings can be quickly approximated for tens of thousands of lines using **publicly available historical** weather data for use in planning and cost/benefit studies



 Moving from nighttime-adjusted ratings to clear-sky-adjusted ratings provides more benefit than moving from clear-skyadjusted ratings to actual-irradiance-adjusted ratings




3. If using real-time temperature and irradiance without adjusting the assumed static windspeed, the incidence of "overrated" hours increases (≤0.61 m/s wind alone is more common than ≥40°C temperature, ≥1000 W/m² irradiance, and ≤0.61 m/s windspeed together)


0.61 m/s perpendicular windspeed for SLR, ALR, NLR, CLR, ILR:

Preliminary


results



4. DLR provides substantially more detail than ILR; the nature of benefits (higher ratings vs avoided "overrating") is sensitive to counterfactual assumptions and line-specific weather patterns



5. Lines with ≥75% of their length above 3 m/s tend to demonstrate larger increases in ratings with DLR than lines below the threshold, but there is significant variability across lines, and many lines below the threshold still show large benefits from DLR; full calculations including hourly wind speed and direction provide more information than heuristics based on average wind speed



Contact information and computer code:

patrick.brown@nrel.gov

https://github.com/NREL/DynamicLineRatings

www.nrel.gov

NREL/PR-6A40-91599

This work was authored by the National Renewable Energy Laboratory, operated by the Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under contract no. DE-AC36-08GO28308. Funding was provided by the U.S. Department of Energy Grid Deployment Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.




Supplementary Information

Abbreviations

ACSR	aluminum conductor, steel reinforced
ALR	ambient-temperature-adjusted line rating
ANOPR	Advanced Notice of Proposed Rulemaking
CIGRE	International Council on Large Electric Systems
CLR	clear-sky-irradiance-adjusted line rating
DLR	dynamic line rating (including wind speed and direction)
FERC	Federal Energy Regulatory Commission
GHI	global horizonal irradiance
HIFLD	Homeland Infrastructure Foundation Level Dataset
IEEE	Institute of Electrical and Electronics Engineers
ILR	measured-irradiance-adjusted line rating
kV	kilovolts
m/s	meters per second
NLR	nighttime-adjusted line rating
NREL	National Renewable Energy Laboratory
NSRDB	National Solar Radiation Database
SLR	static line rating
W/m^2	watts per square meter
WTK	Wind Integration National Dataset (WIND) Toolkit
ZLR	seasonal line rating

Irradiance options





Validation: Wind angle

Convective cooling is strongest when the wind blows perpendicular to the conductor.


These tests show that the line ratings behave as expected:

- In a location where the prevailing wind is from the north and south, an eastwest line has a higher rating than a north-south line
- In a location where the prevailing wind is from the east and west, a north-south line has the higher rating





What if we change the assumed conductor temperature?



What if we change the assumed conductor temperature?

