

Solar Energy Task Force Report Technical Training Guidelines

MASTER

Kevin O'Connor



SERI

Solar Energy Research Institute

A Division of Midwest Research Institute

1617 Cole Boulevard
Golden, Colorado 80401

Operated for the
U.S. Department of Energy
under Contract No. EG-77-C-01-4042

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

SERI/SP-42-345

SOLAR ENERGY TASK FORCE REPORT
TECHNICAL TRAINING GUIDELINES

KEVIN O'CONNOR

OCTOBER 1979

PREPARED UNDER TASK NO. 4228

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Solar Energy Research Institute

1536 Cole Boulevard
Golden, Colorado 80401

A Division of Midwest Research Institute

Prepared for the
U.S. Department of Energy
Contract No. EG-77-C-01-4042

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

geg

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

FOREWORD

The Solar Energy Task Force report summarizes information and discussions generated from the Task Force Workshop of 12-13 September 1978. The Task Force members, leaders in education, labor, and business involved with solar technical training programs, were assembled to study training problems. This report was formally presented at the National Energy Education, Labor, and Business Conference on "Energy-related Vocational and Technician Training, Employment, and Public Energy Awareness" held in Washington, D.C., 15-17 January 1979 under the sponsorship of the Department of Energy (DOE), Office of Education, Business, and Labor Affairs.* The Solar Energy Task Force was stimulated by DOE and coordinated and supported by the Solar Energy Research Institute (SERI).


The Task Force focused on solar space and water heating applications to provide guidelines for technical training courses and curriculum for vocational/technical schools and community/junior colleges. The report addresses questions of curriculum development; jobs, tasks, and skills that require training; and equipment recommendations for establishing a solar training center. The fundamental question of whether or not to offer a solar program is explored.

The contributions of the Solar Energy Task Force members are greatly appreciated. It is hoped that this will be a useful initial document for all those involved in solar technical training.



Kevin O'Connor, Chairperson
Solar Task Force

Approved for SERI:



George Warfield
Director, Technology Dissemination

*The Task Force Report was originally distributed at the 15-17 January 1979 Conference in draft form only. The final, revised version is being produced so that nonconference attendees may benefit. This effort is in partial fulfillment of Task 4228—Vocational Training Programs.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

NOTICE

This report was prepared for DOE by SERI and the Solar Energy Task Force members. Neither the United States, DOE, nor their employees; nor their contractors, sub-contractors, or their employees; nor SERI, nor Task Force member makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Special mention of educational institutions, products, manufacturers, and reference materials is not meant to be an endorsement of such institutions, products, manufacturers, reference materials, etc.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

TABLE OF CONTENTS

	<u>Page</u>
1.0 Introduction	1
2.0 Task Force Summary	3
2.1 Objectives	3
2.2 Cautions and Recommendations	3
3.0 Solar Jobs and Associated Skills	5
3.1 Sales	5
3.1.1 Describe Different Systems.....	5
3.1.2 Show the Finished Product.....	5
3.1.3 Explain Performance	5
3.1.4 Recommend a Particular System	6
3.1.5 Explain System Operation and Maintenance	6
3.1.6 Explain Impact on Comfort	6
3.1.7 Estimate System Costs.....	6
3.2 Designer	6
3.2.1 Select the Proper System.....	6
3.2.2 Select Optimum System Size.....	7
3.2.3 Calculate System Performance.....	7
3.2.4 Provide Details on Operation	7
3.2.5 Describe Installation and Maintenance	7
3.3 Installer	8
3.3.1 Install Collectors.....	8
3.3.2 Make System Connections to Collectors	8
3.3.3 Test For Leakage	8
3.3.4 Locate, Construct, and Install Storage	8
3.3.5 Connect Pipes and Ducts to Storage	8
3.3.6 Install Collector/Storage Heat Exchangers, Pumps, Check Valves, Filters, and Isolation Valves.....	9
3.3.7 Connect the System with a Standard Backup Heating Unit	9
3.4 Electrician	9
3.4.1 Provide Power	9
3.4.2 Install Sensors	9
3.4.3 Install Thermostat.....	9
3.4.4 Connect Mechanical Device Controls to Controller	9
3.4.5 Check Out Control Modes	9
3.5 Supervisor.....	9
3.5.1 Establish a Schedule	9
3.5.2 Conform with Codes	9
3.5.3 Conform Installation with Design.....	10

TABLE OF CONTENTS (concluded)

	<u>Page</u>
3.6 Service and Maintenance Technician	10
3.6.1 Understand the General System Operation	10
3.6.2 Identify the Control Mode of the System	10
3.6.3 Determine If Mechanical Devices Are Operational	10
3.6.4 Identify Points for Fluid Temperature Measurements	10
3.6.5 Determine If Heat Flows Are Nominal	10
3.6.6 Locate Problems	10
3.6.7 Solve Problems	11
3.6.8 Execute Periodic Maintenance	11
3.6.9 Perform System Startup.....	11
4.0 Sample Curricula and Programs	13
4.1 Student Training Programs	13
4.2 Instructor Training Programs	13
4.3 Classroom Source Materials	14
5.0 Equipment Needs for Solar Training.....	15
5.1 Clark County Community College	15
5.2 Community College of Denver, Red Rocks Campus	16
5.3 Navarro College	16
5.4 Scott Community College	16
6.0 References	17
Appendix A - Solar Energy Task Force Members	A1
Appendix B - Predominant Solar Technician Tasks	B1
Appendix C - Predominant Solar Mechanic Tasks	C1
Appendix D - Course Schedule	D1
Appendix E - Equipment List, Clark County Community College	E1
Appendix F - Equipment List, Community College of Denver, Red Rocks Campus	F1
Appendix G - Equipment List, Navarro College	G1
Appendix H - Equipment List, Scott Community College	H1
Appendix I - Classroom Materials Sample, Community Collge of Denver, Red Rocks Campus	I1

SECTION 1.0

INTRODUCTION

The Solar Energy Task Force met 12-13 September 1978 to develop directives for solar energy technical training programs. A group of twelve leaders in solar technical training represented education, labor, and business. See Appendix A for a list of the Task Force members.

This Task Force report offers guidelines for programs oriented to commercial applications in solar energy, specifically water and space heating. The report examines these technologies because they are, in some cases, economically feasible. Any new technical training program must be responsive to current market needs: jobs must be available! Hence, concentration on other solar applications and alternate sources of energy was not considered. The Task Force report suggests sample curricula and programs, technical jobs and skills, and equipment to assist those institutions contemplating the development of technical training. Even though the report concentrates on active systems for space heating and hot water, a well-rounded program should focus early on energy conservation and the incorporation of passive design in new and existing buildings.

SERIO 

SECTION 2.0

TASK FORCE SUMMARY

2.1 OBJECTIVES

The Solar Energy Task Force met to accomplish three goals that might provide information on technical training programs for people in education, labor, and business. The three objectives were:

- Solar Jobs and Associated Skills. The following jobs are those necessary for solar training programs: (a) Sales, (b) Designer, (c) Installer, (d) Electrician (not necessarily trained in the solar program, but needed in some solar installations), (e) Supervisor, and (f) Service/Maintenance Technician. Section 3.0 presents tasks and skills required for each job. A person may perform more than one job. These jobs might better be viewed as functions required in a solar installation. The size and complexity of the installation determine the jobs necessary.
- Sample Curricula and Programs for Students and Instructors. Institutions considering solar education often ask: Where do I start? What programs already exist? How do I get more information? Section 4.0 and Appendix I attempt to respond to these questions. Many curricula, programs, and courses are being offered across the United States [1, 2]. The draft version of the Task Force report presented sample curricula from five selected schools. Since Refs. 1 and 2 are comprehensive, these curricula are not included in this revised version. Insufficient solar experience prohibits one from judging which program is the best. Different programs meet various needs. For example, an educational program that retrains already skilled individuals need not be as comprehensive as one for the high school graduate who needs training at the job entry level. Therefore, critical to program development is the selection of the target audience. In addition to student curricula, there is a need for programs directed toward instruction of the teacher. The programs for teachers offered at Colorado State University and the League for the Innovation of Community Colleges are described in Sec. 4.0.
- Equipment Needs. Training requires special equipment for the classroom and laboratory. In emergent solar technology, there are only a few teaching programs and tested equipment for optimum classroom and laboratory experience. Section 5.0 and Appendices E through H suggest equipment that has been developed or proved useful. Although the purchase cost of solar equipment and teaching aids might be \$20,000, a cost of \$50,000 is probably not unreasonable for a well-equipped hands-on situation.

2.2 CAUTIONS AND RECOMMENDATIONS

In addition to the major objectives cited, many important issues were discussed, some of which directly impinge on the decision to offer solar courses.

- In general, the Task Force does not advocate that persons be educated strictly as solar technicians, mechanics, or installers, etc. Because the demand for purely solar jobs is uncertain, training a person for job entry as a "solar" anything might

not assure employment. The direction of solar energy, however, may be dramatically altered with the passage of the National Energy Act, additional solar incentive legislation, state and local assistance, and other promotional activities. Were the Task Force to meet again within the coming year, it might advocate solar-specific job training. At the Community College of Denver, Red Rocks Campus, in Golden, Colo., where a two-year solar technician's training program is into its second year, Craig Hilton, Solar Energy Instructor, indicates that nearly all of his students find solar employment. But follow-up studies on continued employment in the solar field are necessary.

- When creating a solar program, an educational institution must understand the contents of the curriculum and coursework, the required tasks and competency levels for the personnel, and the equipment necessary for the solar laboratory. Sections 3.0 through 5.0 address those needs in detail.
- The technical training school should use an Advisory Council composed of members of local industry, solar installers and contractors, labor organizations, building contractors, etc. The Advisory Council serves these functions: (1) makes recommendations on solar programs related to technical training needs, (2) maintains awareness within the school of the manpower required in the solar market to help alleviate mistraining or overtraining, (3) provides speakers for programs, and (4) creates links with business and industry to facilitate job placement. Solar program offerings can be quite diverse in both content and length. A large portion of students enrolled in solar education programs are already gainfully employed and older than the average student. Each institution must consider the variety of solar jobs for which it could train students and whether each program will educate students at the job entry level, will retrain them, or will intensify their awareness of current solar applications.
- A person receiving solar training should be well-rounded in Heating, Ventilating, Air Conditioning (HVAC) and plumbing fundamentals. Schools and institutions already offering HVAC and plumbing programs can most easily expand to offer solar training. Students undergoing programs at the job entry level should be skilled in HVAC and plumbing with solar emphasis. In general, the Task Force held that solar specialization at the community or junior college level should be added only in response to community needs.
- The Task Force advocated that there was no need to educate a "solar" engineer. Engineers would be trained in a traditional discipline with specialization in solar energy, which would not preclude entrance into other lines of work.

SECTION 3.0

SOLAR JOBS AND ASSOCIATED SKILLS

An educational institution should understand the variety of jobs for which students of solar energy need to be trained. Not every institution or program will educate students to be proficient in each of the jobs necessary for a successful solar installation. Some schools may offer only one or two courses that heighten community awareness, whereas others might give a full two-year curriculum that trains the "solar" mechanic or technician.

The Task Force identified six jobs that may be essential for solar installations. The jobs include the following: (1) Sales, (2) Designer, (3) Installer, (4) Electrician (not necessarily trained in the solar program), (5) Supervisor, and (6) Service (maintenance). Depending on his orientation and training, a person will be proficient in one or more of these jobs.

The tasks or skills associated with each job are detailed by the Task Force and will help to create curriculum tailored toward specific jobs. The jobs and their attendant skills are detailed in this section.

3.1 SALES

The salesman with insufficient solar knowledge will be detrimental to solar commercialization. Sales personnel must be knowledgeable about solar applications and should be able to perform the following activities.

3.1.1 Describe Different Systems

The sales person should be aware of all solar heating and cooling systems, including domestic hot water applications. They must also understand conventional HVAC and plumbing and the consonance of solar systems with various conventional types if solar retrofits are used. They must be able to properly match solar systems with HVAC systems.

3.1.2 Show the Finished Product

The sales person should explain the details of the finished system, including its appearance on the building, the location of its various components, and structural impacts of the system on the building.

3.1.3 Explain Performance

The sales person must describe the anticipated performance of the solar system, its operation with the conventional system, and its average energy deliverance to the building. The sales person must be able to demonstrate the expected energy savings of the system.

3.1.4 Recommend a Particular System

The sales person must be sufficiently familiar with solar componentry to recommend an optimum system for each application. Knowledge of the most compatible components and of their successful size and design for system operation will also be necessary.

3.1.5 Explain System Operation and Maintenance

The sales person must clearly explain the various modes of operation. He should detail each mode and explain the method by which controls will activate the various modes; designate which pumps, motors, blowers will be active in each mode; and indicate the open/close positions of various valves and dampers for each system. The sales person must know the maintenance operations and intervals for each system installation.

3.1.6 Explain Impact on Comfort

The sales person must be able to explain any possible influence of the solar system on comfort. Potential impacts on humidity, time/temperature fluctuations, and noise levels should be explicated.

3.1.7 Estimate System Costs

The customer will be particularly interested in the additional cost of a solar system for a retrofit or the cost above the conventional system for a new installation. The sales person must know how to estimate costs of components, labor, energy usage, etc. An estimate of system savings on the energy bill and of investment payback periods must be attained.

The sales person must be knowledgeable of local, state, and federal solar incentive programs for tax credits, applicable rebates, etc. An understanding of local building codes and insurance practices to solar construction will also be necessary.

3.2 DESIGNER

The system designer lays out the details of the solar system. The designer, therefore, will be the main interface between the project architect and mechanical engineer. The system designer will provide the intricacies that will insure successful system installation and interconnection with the conventional HVAC system. Therefore, detailed operational knowledge of conventional and solar systems is needed. The system designer must execute the duties listed in Secs. 3.2.1 through 3.2.5.

3.2.1 Select the Proper System

From among the myriad solar systems available, the system designer must be able to select the system that best meets the building's heating/cooling load requirements, answers geographic considerations, integrates into the architectural design, complies with the maximum structural stress for the area in which the system is integrated, and meets local code requirements.

3.2.2 Select Optimum System Size

Even though larger systems with properly sized storage will yield more energy to the consumer, there is a point on the cost/benefit scale beyond which it is imprudent to invest in a larger system. (In addition, available collector surface area may be exceeded). The system designer must select the optimum system size based on his knowledge of its performance and of system economics. The method of calculating optimum system size and the appropriate tools (usually computer/calculator program) for the job (for example, FCHART, SOLCOST, etc.) must be part of the designer's repertoire.

3.2.3 Calculate System Performance

The system designer should be able to calculate system performance for any geographic location. He should know how to calculate building heat loads for sizing the system (Section 3.2.2) and how to merge this information into the predicted energy savings of the solar system. Tools that help one to select optimum solar system size such as FCHART and SOLCOST, are useful in calculating system performance [3].

3.2.4 Provide Details on Operation

The system designer must be able to create the necessary drawings, charts, tables, etc., which size and locate solar system components in the buildings. Drawings and charts should sufficiently explain the various modes of operational detail for the architect and mechanical engineer. The detailed drawings should also be complete enough to be used by the installer, electrician, supervisor, and maintenance persons. The operational detail will include the following:

- Specific drawings and descriptions of each mode of operation, including location of ducts, dampers, valves, etc. for the particular mode;
- Operational ranges of system controls for each mode;
- Collector placement, altitude and azimuth angles, and attachment to building structure;
- Detailed drawings and descriptions of piping and duct connections, sizing, flow balancing, etc.;
- Component sizing and location of collectors, pumps, blowers, and storage; and
- Meticulous drawings and descriptions of the storage component and interconnections.

3.2.5 Describe Installation and Maintenance

The information itemized in Sec. 3.2.4 should provide details necessary for the system installer. In addition, the system designer should describe the routine anticipated maintenance operations and attendant schedules.

3.3. INSTALLER

System installers will need to intricately understand installation and construction of solar component hardware, as well as HVAC and plumbing systems. In addition, they should have a specific knowledge of system operation, design, maintenance, and local building codes. The installer is the hands-on person capable of translating the designer's blueprints into a properly installed system. The installer should demonstrate good craftsmanship in all his work and toward this end should be able to perform the activities given next.

3.3.1 Install Collectors

The installer must be familiar with a variety of installation techniques, mounting hardware, and collector interconnections. The installer must be able to mount, fasten, and flash collectors to insure that collectors and support structures will withstand the local climate (wind, hail, snow, etc) and prevent roof leakage and rot.

3.3.2 Make System Connections to Collectors

The installer must be totally familiar with the necessary connections in each solar system, including both air and liquid. The installer must know the various fittings and unions and the soldering and sheet metal techniques used in making connections. To assemble collectors and establish system connections, one must understand and incorporate allowances for thermal expansion.

3.3.3 Test for Leakage

Prior to installation, collectors should be tested for both internal leakage in the absorber plate and external leakage through the collector housing. The installer must also be able to flush a liquid system, fill it with the appropriate fluid, and pressure test it for leaks.

3.3.4 Locate, Construct, and Install Storage

The installer should be familiar with various storage systems, containers, tanks, etc., that can be employed in solar systems. The installer should be able to construct storage systems, usually rock storage bins with air systems. One should know the proper locations for the tank or storage bin, i.e., allow room for interconnections, insulation, servicing, etc.

3.3.5 Connect Pipes and Ducts to Storage

The installer must be able to read designer blueprints to connect pipes and air ducts to the storage container, which includes (in addition to Task 3.3.2) the proper pitching of pipes and use of appropriate insulation (right type and R-Value) of pipes and ductwork. This task would also involve the installation of storage sensors connected to the system controller.

3.3.6 Install Collector/Storage Heat Exchangers, Pumps, Check Valves, Filters, Isolation Valves, and Other Hardware that Affects the Collector/Storage Operation.

3.3.7 Connect the System with a Standard Backup Heating Unit, Including Filters, Humidifiers, etc.

3.4 ELECTRICIAN

The electrician will be used for the installation of solar controls. He may be unfamiliar with the detailed operation of solar systems, but he should be able to interpret the system information (drawings, blueprints, etc.) for successful hookup of the solar control system. On smaller systems, usually retrofits, an electrician may be unnecessary because there is no need to connect wiring to the main service box or to work directly with the 110 vac lines. In larger systems, especially those of commerce and industry, an electrician will be needed. The electrician must be trained to perform the following duties.

3.4.1 Provide Power To Main Control Unit, Blowers, Pumps, and Any Safety Controls in the Systems

3.4.2 Install Sensors Or Insure That They Are Properly Installed

3.4.3 Install Thermostat

3.4.4 Connect Mechanical Device Controls to Controller

3.4.5 Check Out Control Modes with the Person Responsible for System Startup

3.5 SUPERVISOR

The supervisor of the construction and installation of solar systems will need to perform these tasks.

3.5.1 Establish a Schedule

The supervisor will need to coordinate the delivery of materials with manpower schedules to insure that the installation proceeds smoothly.

3.5.2 Conform with Codes

The supervisor must be certain that the solar installation does not violate any of the local building codes, ordinances, etc.

3.5.3. Conform Installation with Design

The supervisor must continuously inspect the system being installed to insure that it is without variance, unless approved, to the original system design.

3.6 SERVICE AND MAINTENANCE TECHNICIAN

The service or maintenance technician needs to be erudite about solar system operations. The service person must be able to perform the activities included in Secs. 3.6.1 through 3.6.9.

3.6.1 Understand the General System Operation

Before tackling maintenance, the service technician must have a practical knowledge of each system.

3.6.2 Identify the Control Modes of the System

The technician should know controller circuitry and associated wiring, the proper location and installation of sensors, and the temperature ranges and control points of system modes.

3.6.3 Determine If Mechanical Devices are Operational

The service person must have experience with motor repair and operation and with various valves (gates, balancing, pressure-temperature relief, air vents, solenoid, etc.).

3.6.4 Identify Points for Fluid Temperature Measurements

He must be able to determine if sensors are properly installed and in the proper locations.

3.6.5 Determine if Heat Flows are Nominal

Also, he must know the principles of heat transfer and make calculations based on temperature measurements to determine if the actual heat flows as compared to theoretical flows are within the acceptable tolerances.

3.6.6 Locate Problems

The technician must coordinate system knowledge, system operation, and testing and measuring techniques to localize any problems.

3.6.7 Solve Problems

When the problem is isolated the maintenance person should solve it. In some instances, he may have isolated the problem, but will be unable to repair it himself. He then must know the person to contact to correct the trouble.

3.6.8 Execute Periodic Maintenance

The service person should maintain pumps, motors, blowers, and anti-freeze, depending on the system type. Changes of filters and system flushing may be needed in certain systems. The maintenance person should perform all maintenance specified by the system designer.

3.6.9 Perform System Startup

On small system installations (swimming pool and domestic hot water), system startup will be done by the service/maintenance person. Ability to perform the above tasks should assure proficiency in correcting problems of smaller systems. In larger, more complex systems, especially in commerce and industry, system startup will be performed by one knowledgeable in large-scale applications, and informed about total system operation (design function), installation, electrical operation, and service/maintenance requirements. Assurance that the system is properly operating is the task of the system startup person. In large systems, this person (who may be the mechanical contractor) may be supervising a team as the system is engaged.

Section 3.0 has focused on six jobs. An alternate approach to classification of jobs and tasks was done in a master's thesis by William D. Hunt of California State University at Chico, Calif., titled "Solar Technicians and Mechanics: a Preliminary Occupational Task Analysis." Given in this thesis are detailed task requirements for two jobs in the emerging solar heating and cooling industry. Appendices B & C list predominant solar technician and mechanic tasks.

SERIO 

SECTION 4.0

SAMPLE CURRICULA AND PROGRAMS

4.1 STUDENT TRAINING PROGRAMS

When the Task Force report was originally written in draft form, the National Solar Energy Education Directory, First Edition [1] and the Solar Energy Technical Training Directory [2] were not yet in print. With the availability of these reports, it is unnecessary to list solar curricula, programs, and courses. Anyone interested should consult these documents.

4.2 INSTRUCTOR TRAINING PROGRAMS

- Department of Energy - Community College Instructor Training

Contact: Debra Langford (202) 376-1983. Conservation and Solar Applications, DOE, Room 2221C, 20 Massachusetts Avenue, N.W., Washington, D.C. 20545.

Under contract with DOE's Solar Technology Transfer Program, the League for Innovation in the Community College, a national consortium representing 50 colleges, is developing curriculum material and procedures for training community college instructors who must teach solar installation skills. Specifically, the project will:

- Train a minimum of 60 community college vocational/technical faculty members from 9 districts (38 colleges) in the western United States to teach skills necessary for the installation of solar systems.
- Train two-member teams from the nine districts to develop and implement training programs for solar system installers.
- Duplicate the program for Eastern/Midwestern community college districts from the results of the Western Region Program.
- Explore training by television for solar system installers.
- Develop a training format for installers.
- Establish a network for the community college districts to share information about solar systems.

- Colorado State University

Contact: Dr. Susumu Karaki, Director, Solar Energy Applications Laboratory, Colorado State University, Fort Collins, Colo. 80523.

The Colorado State University's Solar Energy Applications Laboratory has developed two of the most comprehensive manuals for training the solar instructor and practitioner. The titles are: Solar Heating and Cooling of Residential Buildings: Sizing, Installation and Operational Guidelines [4], and Solar Heating and Cooling of Residential Buildings: Design of Systems [5]. The modular course has been offered in one week schedules (See Appendix D), but some schools are using the manuals, with supplemental information, as the basis for training programs. Each manual is over 700 pages.

4.3 CLASSROOM SOURCE MATERIALS

Books and documents are available for the technical training classroom. One should review a sample of source materials used in an actual program, such as that of the Community College of Denver, Red Rocks Campus (Appendix I). A more detailed "Reading List for Solar Energy" (latest edition) can be obtained from the National Solar Heating and Cooling Information Center, P.O. Box 1607, Rockville, MD 20850.

SECTION 5.0

EQUIPMENT NEEDS FOR SOLAR TRAINING*

The cost and process of setting up a laboratory for solar training has varied greatly from institution to institution. In general, the Task Force agreed that for approximately \$20,000 an effective solar laboratory could be initiated. If the entire funding is not available in the beginning of a program, it is proposed that the equipment be purchased in stages. The suggested costs of equipment for the sample schools listed are summarized:

<u>School</u>	<u>Solar Equipment Costs</u>
Clark County Community College, North Las Vegas, Nev.	\$57,275
Community College of Denver - Red Rocks Campus, Golden, Colo.	\$21,000
Navarro College, Corsicana, Tex.	\$45-\$55,000
Scott Community College, Bettendorf, Iowa	\$54,000

Because solar educational offerings are embryonic, development of standard laboratory equipment for solar energy is also in its infancy. Sample lists of major equipment that are in use or are planned for technical training programs in several community colleges are presented. The emphasis is on hands-on equipment, models, and diagnostic training aids.

5.1 CLARK COUNTY COMMUNITY COLLEGE

Highly innovative equipment is used in the Clark County Community College Solar Program. All equipment is designed to promote a logistically integrated educational program. Much of it centers around a Central Control Monitoring Package (CCMP). This unit can control most active solar systems, from the simplest to the most complex, as well as collect and record data from various energy systems. Designed and built especially for Clark County Community College is the unique Modular Liquid System Trainer (MLST), having totally interchangeable components of tanks, pumps, valves, heat exchangers, pipes, etc. Any assembled system can be monitored and controlled with the CCMP.

Useful collector arrays consist of various liquid collectors including a simple unglazed swimming pool type, a single-glazed nonselective flat plate, a double-glazed selective flat plate, an evacuated tube module, and a concentrating parabolic tracker. Air systems may be simulated with a unique 1/8 scale Model Air System. By the use of model passive homes and temperature monitoring through the CCMP, passive solar systems may be studied. For practical experience in installing and maintaining solar swimming pool collectors, a simulated roof-mounted solar swimming pool collector unit is provided at

*Any reference to specific manufacturers or products is not an endorsement of any product or service, but is listed for information purposes only.

ground level to assemble, repair, and disassemble. Apparatuses and prices used in the Clark County Community College Program are found in Appendix E.

5.2 COMMUNITY COLLEGE OF DENVER, RED ROCKS CAMPUS

The list of equipment for the Certificate and Associate Degree Program of the Community College of Denver, Red Rocks Campus, is found in Appendix F.

5.3 NAVARRO COLLEGE

Navarro College offers the one-year solar mechanics program and expects to offer the solar technician program in the fall of 1979. A list of major equipment proposed by Navarro College is found in Appendix G.

5.4 SCOTT COMMUNITY COLLEGE

The equipment list used by Scott Community College for their technical training program is presented in Appendix H.

SECTION 6.0

REFERENCES

1. Corcoleotes G.; Kramer K.; O'Connor K.; Silversmith J. National Solar Energy Education Directory, First Edition. Golden, CO: Solar Energy Research Institute. SERI/SP-42-141; Jan. 1979. Available from: Superintendent of Documents, U.S. Government Printing Office, Washington, D.C., 20402, 061-000-00210-3. Price: \$4.75.
2. Corcoleotes G.; Kramer K.; O'Connor K. Solar Energy Technical Training Directory. Golden, CO: Solar Energy Research Institute. SERI/SP-84-282; June 1979. Available from: SERI Document Distribution Service, 1536 Cole Blvd., Golden, CO. 80401 and the National Solar Heating and Cooling Information Center, P.O. Box 1607, Rockville, MD 20850.
3. Solar Energy Research Institute. Analysis Methods for Solar Heating and Cooling. Golden, CO. SERI/SP-35-232. Available from: SERI Document Distribution Service, 1536 Cole Blvd., Golden, Colo. 80401.
4. Solar Energy Applications Laboratory. "Solar Heating and Cooling of Residential Buildings: Sizing, Installation and Operation of Systems. Fort Collins, CO: Colorado State University; Jan. 1977. Available from: Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402, S/N 003-011-00085-2. Price: \$8.25.
5. Solar Energy Applications Laboratory. Solar Heating and Cooling of Residential Buildings: Design of Systems. Colorado State University, Solar Energy Applications Laboratory; Jan. 1977. Available from: Superintendent of Documents, U.S. Government Printing Office, Washington, D.C., 20402, S/N 003-011-00084-4. Price: \$7.50.

SERIO 

APPENDIX A
SOLAR ENERGY TASK FORCE MEMBERS

SERIO 

Mr. O.C. Burnell
 Director of Instruction
 Scott Community College
 Belmont Road
 Bettendorf, Iowa 52722
 (319) 359-7531

Mr. Peter Colaianni
 Solar Energy Industries Association
 1001 Connecticut Avenue, N.W., Suite 800
 Washington, D.C. 20036
 (202) 293-2984

Mr. David Comarow
 Clark County Community College
 3200 East Cheyenne Avenue
 North Las Vegas, Nev. 89030
 (702) 643-6060, Ext. 396

Mr. David E. Herrington (not in attendance)
 Admin. Assistant for Technological
 and Educational Programs
 National Training Fund
 Sheet Metal and Air Conditioning Industry
 1900 L Street, N.W., Suite 405
 Washington, D.C. 20036
 (202) 833-9543

Mr. Craig A. Hilton
 Community College of Denver
 Red Rocks Campus
 12600 West 6th Avenue
 Golden, Colo. 80401
 (303) 988-6160, Ext. 225

Mr. Robert N. Illingsworth
 Director, Research & Development
 Eastern Iowa Community College District
 2804 Eastern Avenue
 Davenport, Iowa
 (319) 322-5015

Dr. Susumu Karaki, Director
 Solar Energy Applications Laboratory
 Colorado State University
 Fort Collins, Colo. 80523
 (303) 491-8617

Mr. Robert Martinez
 National Training Fund
 Sheet Metal and Air Conditioning Industry
 1656 S. Jellison Street
 Lakewood, Colo. 80226
 (303) 986-8990

Mr. Kevin O'Connor
 Task Force Chairperson
 Solar Energy Research Institute
 1617 Cole Boulevard
 Golden, Colo. 80401
 (303) 231-1825

Mr. Allyn Parmenter, Director
 United Assn. of Journeymen & Apprentices of
 the Plumbing & Pipe Fitting Ind. of
 the United States and Canada
 901 Massachusetts Avenue, N.W.
 Washington, D.C. 20001
 (202) 628-5823

Mr. Robert Zimbelman
 Manager of Education Program Development
 Education Department
 Lennox Industries, Inc.
 Promenade Tower
 Box 400450
 Dallas, Tex. 75240
 (214) 783-5230

Ms. Revonda Williams (DOE Coordinator)
 Education Programs Division
 Department of Energy
 400 First Street, N.W., Room 307
 Washington, D.C. 20545
 (202) 376-9211

SERIO 

APPENDIX B
PREDOMINANT SOLAR TECHNICIAN TASKS

SERIO 

Solar Technician Task Requirements^a

- Read blueprints and schematics.
- Calculate heat loss/gain in buildings.
- Size solar collector array.
- Prescribe appropriate automatic solar controls.
- Size water storage sub-systems.
- Draft blueprints and schematics.
- Perform supervisory functions.
- Trouble-shoot, maintain, and repair solar controls.
- Size or prescribe solar plumbing, to include pumps, based on "rule of thumb" procedures.
- Size solar-assisted heat-pump systems.
- Size auxiliary backup heating systems.
- Size or prescribe solar plumbing, to include pumps, based on flow rates, friction loss, and other data.
- Size heat exchanger units.
- Size rock storage subsystems.
- Sell solar apparatus.
- Size or prescribe solar pond or solar wall (thermal mass) systems.
- Size south-facing window systems.
- Prescribe types of movable insulation and apparatus in passive systems.
- Perform administrative functions.
- Calculate heat loss/gain in storage systems.
- Maintain and repair solar collector array.
- Design duct work requirements.

^aFrom Hunt, William D. Solar Technicians and Mechanics: A Preliminary Occupational Task Analysis. San Diego, CA, 7283 Engineer Rd., Suite G: Southwest Energy Mangement, Inc.

Solar Technician Task Requirements (concluded)

- Size or prescribe heating ducts, vents, and blowers based on "rule of thumb" procedures.
 - Size or prescribe heating ducts, vents, and blowers based on flow rates, friction loss, and other data.
 - Calculate heat loss/gain in plumbing and duct systems.
 - Maintain and repair solar plumbing.
-

APPENDIX C
PREDOMINANT SOLAR MECHANIC TASKS

SERIO 

Solar Mechanic Task Requirements^a

- Install and wire solar control systems.
- Read blueprints and schematics.
- Cut and join plastic pipe/plumbing.
- Install solar collectors on roofs.
- Maintain and repair solar collector array.
- Maintain and repair solar plumbing.
- Maintain and repair solar blowers and fans.
- Cut and braze copper pipe/tubing.
- Install prefabricated sheet metal parts.
- Install solar collector array or solar furnace at ground level.
- Maintain and repair solar water pumps.
- Install water storage sub-systems.
- Install living area/space heat exchanger units.
- Build and install rock storage sub-systems.
- Install solar-pond or solar-wall (thermal mass) systems.
- Soft-solder electrical wires and connections.
- Install auxiliary backup heating systems.
- Modify existing furnace to accept solar apparatus.
- Cut and install glass or plastic glazing in collectors.
- Install movable insulation and apparatus in passive systems.
- Modify or relocate existing plumbing and exhaust vents on roof.
- Install heating ducts and vents.
- Install solar-assisted heat pumps.
- Trouble-shoot, maintain and repair solar controls.
- Silver braze copper alloy pipe and sheets.
- Cut, bend, and fabricate sheet metal parts.
- Perform supervisory functions.
- Cut, thread, and install galvanized pipe/plumbing.

^aFrom Hunt, William D. Solar Technicians and Mechanics, a Preliminary Occupational Task Analysis.

SERIO 

APPENDIX D
COURSE SCHEDULES
COLORADO STATE UNIVERSITY

SERIO 

From Solar Heating and Cooling of Residential Buildings: Design of Systems, Solar Energy Applications Laboratory, Fort Collins, Colo. p. 1-3.

D3

Figure D-1. COURSE SCHEDULE

	SUNDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY
0800		MODULE 2 (45 min) Course Orientation	OPEN DISCUSSION (30 min)	OPEN DISCUSSION (60 min)	OPEN DISCUSSION (30 min)	OPEN DISCUSSION (30 min)
		MODULE 3 (75 min) Introduction to Solar HAC Systems	MODULE 6 (90 min) Thermal Storage Subsystems	MODULE 10 (60 min) Solar Heating and Cooling Systems	MODULE 13 (90 min) Heating Load Calcula- tions	MODULE 17 (90 min) Cost Effectiveness of Energy Conservation
1000		COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)
		MODULE 4 (90 min) Solar Radiation	MODULE 7 (90 min) Service Hot Water Systems	MODULE 11 (45 min) Control Subsystems	MODULE 14 (60 min) Solar System Sizing	MODULE 18 (45 min) Retrofit Considera- tions
				MODULE 12 (45 min) Operations Laboratory	MODULE 15 (30 min) System Economics	MODULE 19 (45 min) Scheduling of Solar Installations
1200		LUNCH (60 min)	LUNCH (60 min)	LUNCH (60 min)	LUNCH (60 min)	LUNCH (60 min)
1300		MODULE 4 cont (60 min) Solar Radiation	MODULE 8 (120 min) Solar Heating Systems	MODULE 12 cont (240 min) Operations Laboratory	MODULE 15 cont (30 min) System Economics	MODULE 20 (60 min) Constraints and Incentives
1400	REGISTRATION Solar House Tours	MODULE 5 (60 min) Fluid-Heating Solar Collectors			MODULE 16 (90 min) Solar System Sizing Calculations	MODULE 21 (60 min) Buyer's Guide
1500		COFFEE (30 min)	COFFEE (30 min)		COFFEE (30 min)	COFFEE (30 min)
		MODULE 5 cont (90 min) Fluid-Heating Solar Collectors	MODULE 8 cont (30 min) Solar Heating Systems		MODULE 16 cont (90 min) Solar System Sizing Calculations	Final Discussion and Critique (90 min)
			MODULE 9 (60 min) Solar Space Cooling Systems			
1700		ADJOURN	ADJOURN	ADJOURN	ADJOURN	ADJOURN
1730	RECEPTION AND DINNER MODULE 1 (30 min) Energy Problem					AWARDS DINNER MODULE 22 Future Prospects for Solar HAC Systems

Figure D-2. COURSE SCHEDULE

	SUNDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY
0800		MODULE 1 (30 min) Course Orientation	REVIEW AND QUESTIONS (30 min)	REVIEW AND QUESTIONS (30 min)	REVIEW AND QUESTIONS (30 min)	REVIEW AND QUESTIONS (30 min)
		MODULE 2 (90 min) General Descriptions of Solar Heating and Cooling Systems	MODULE 7 (90 min) Detailed Design Methods	MODULE 11 (90 min) Collectors	MODULE 15 (90 min) System Controls	MODULE 20 (90 min) Design Case Study
1000		COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)
		MODULE 3 (90 min) Solar Radiation Information for Design Purposes	MODULE 7 cont (30 min) Detailed Design Methods	MODULE 11 cont (30 min) Collectors	MODULE 16 (90 min) Selection of Subsystem Components	MODULE 21 (45 min) Structural, Mechanical and Scheduling Considerations
			MODULE 8 (60 min) Economic Considerations	MODULE 12 (60 min) Storage Systems		MODULE 22 (45 min) Future Prospects for Solar Heating and Cooling Systems
1200		LUNCH (60 min)	LUNCH (60 min)	LUNCH (60 min)	LUNCH (60 min)	LUNCH (60 min)
1300	1400 - Registration 1445 - Solar House Tours	MODULE 4 (60 min) System Design Guidelines	MODULE 9 (120 min) Energy Conservation Trade-offs	MODULE 13 (120 min) Laboratory	MODULE 17 (120 min) Solar Cooling Systems	MODULE 23 (60 min) Buyer's Guide
		MODULE 5 (60 min) Heating and Cooling Load Analyses				Review and Summary (60 min)
1500		COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)	COFFEE (30 min)
		MODULE 6 (90 min) Simplified Design Calculations	MODULE 10 (90 min) Detailed Design Calculations	MODULE 14 (90 min) Computer-Aided F-Chart Calculations	MODULE 18 (45 min) Automated Design Techniques	Evaluation of the Course by participants
					MODULE 19 (45 min) Service Hot Water Systems	
1700		ADJOURN	ADJOURN	ADJOURN	ADJOURN	ADJOURN
1730	Reception and Dinner					Dinner and Awards

APPENDIX E
EQUIPMENT LIST
CLARK COUNTY COMMUNITY COLLEGE

SERI 

Supplied by David Comarow^a

<u>Instrumentation</u>	<u>Price</u>
Flow meters, strip chart recorder	\$2,500
Calculator, with Software	575
6 Computer Terminals	7,100
Hand tools	2,700
<u>Simulators^b</u>	
Controller Bread Board Trainer	
2 Modular Liquid System Trainers (MLS)	38,000
2 Central Control Monitoring Packages (CCMP)	
Omnidata Solar Simulator	
Model Air System	
Collector Arrays and Installation - 5 collectors	6,400
	<u>\$58,275</u>

In addition to the above equipment, Clark County Community College paid \$12,000 to the Desert Research Institute for a needs assessment study, a program assessment study, and the development of three computer programs used in the training program.

^aSee Appendix A for contact information.

^bThe simulators were built at cost by the Energy Systems Center of Desert Research Institute.

SERIO 

APPENDIX F

**COMMUNITY COLLEGE OF DENVER
RED ROCKS CAMPUS
SOLAR ENERGY INSTALLATION AND MAINTENANCE PROGRAM**

SERIO 

Supplied by Craig Hilton^a

<u>Instruments</u>	<u>Cost</u>
2 Heliotrope General Strip Chart Recorders, Model SCR-10	\$780.00
2 Heliotrope General Electronic Thermometers, Model ET10	258.00
1 Heliotrope General Thermometer, Model ET/DT3	96.00
1 Heliotrope General Thermometer, Model HH-230	83.00
Assortment of Heliotrope General Sensors	100.00
1 Texas Instrument TI-59 Programmable Calculator	270.00
1 Printer for above calculator, Model PC-100A	180.00
1 Hastings Air Meter, Model 6-11	150.00
1 Extension cable for above meter, Model CF-12-CM	14.00
1 T.I.F. Volume-Aire Air Balancer, Model VA-105	100.00
1 Rho Sigma Photovoltaic Pyranometer, Model RS1008	135.00
1 Rho Sigma Single Track Recorder for above, Model RS1009	280.00
2 Heliotrope General Electronic Thermometers, Model ET0/350	200.00
Heliotrope General TES-1 Sensors	100.00
1 Meter-Master Digital Multimeter, Model 461	150.00
Subtotal	\$2,896.00
<u>Equipment:</u>	
1 Grumman Domestic Hot Water Package, Model 60FFT	\$1,150.00
2 Grumman double glazed collectors, Model 60F	550.00
8 Sungrabber 2'x10' Collectors with Black Chrome Rocky Mountain Products, Denver, Colo.	2,500.00
1 Domestic Hot Water System, Lordan Collectors (three), Mountain Mechanical Sales, Denver, Colo.	1,156.00
2 Soloron Air Collectors plus mounting hardware, Model CL 2003X, Capture Energy Products, Inc., Denver, Colo.	1,175.00
2 Soloron Air Collectors plus mounting hardware, Model CL 2003Y, Capture Energy Products, Inc., Dener, Colo.	1,175.00
1 Solar Air Handling Unit with thermostat and controls	300.00
5 Misc. Delta Ts and other components	500.00
1 80 Gal. Sepco Storage tank with removable heat exchanger, Capture Energy Products, Inc., Denver, Colo.	504.00
1 Domestic Hot Water System, including 2 Insolarator Collectors, Model SA120-1255, Mountain Mechanical Sales, Denver, Colo.	1,100.00
Subtotal	\$10,110.00

^aSee Appendix A for contact information.

Miscellaneous

Hand and power tools, pumps, torches,
welding equipment, collector glazings, copper sheets,
piping and ducting materials, insulation, selective
surface material, demonstration equipment, etc.

\$8,000.00

Grand Total

\$21,006.00

APPENDIX G
EQUIPMENT LIST - NAVARRO COLLEGE

SERIO 

Whereas this equipment provides detailed reference information to specific manufacturers, it is not meant to be an endorsement of the specific product or equipment. The detail is given to provide enough information that similar component considerations can be made and compared. Information on Navarro College's equipment was given to the author by Michael Z. Lowenstein, who was project Director and is now a staff member with SERI.

Closed Loop Domestic Hot Water System

1 Lennox "Solar Mate" Hot Water System - 3 Collectors (double glazed) including pump, proportional flow controller, expansion tank, storage tank with heat exchanger (82 gallon), and tempering valve	\$1,760
1 Similar system except with single glazed collectors	1,650
2 Flow meters (approximately \$90 each)	<u>180</u>
Total for Systems	\$3,590

Complete Solar Systems

Minimum-sized operational liquid and air systems

Air System Equipment

Collectors - 200 square feet (Solaron, \$16.50 per square foot)	\$3,300
Insulated Air Ducting - 200 feet (\$3.50 per foot)	700
Solar Air Mover, including differential thermostat, blower, and motorized dampers (Solar Control Corp. including 25% educational discount)	1,195
Solarstat Solid State Solar System Monitor (Solar Control Corp. including 25% educational discount)	230
Domestic Hot Water Sub-Assembly, including air-water heat exchanger, circulating pump, and storage tank	330
Energy Storage System, rockbed, 200 cubic feet, 5' x 25' x 8' high. Constructed on-site. Includes: plywood and lumber, insulation, rock.	500

Water System Equipment

Collector - 200 Square feet (numerous manufacturers, \$16.50/sq.ft.)	\$3,300
Insulated Piping - 200 feet at \$2.00 per foot	400
Circulating Pumps, 2 (Grundfos Pump UPS20-42-F, \$75.00)	150
Storage Tank, 600 gallon, low pressure	660
Solenoid Valves (Skinner 4 at \$45.00 each)	180
Differential Controller (Hawthorne Variflow II-1510)	70

Liquid-Liquid Heat Exchanger, 2 (one for collector loop, one for providing heat load to system \$440.00 each)	880
Liquid-Air Heat Exchanger with Blower	440
Anti-freeze, 10 gallons at \$4.00 per gallon	<u>40</u>
Subtotal	\$12,375

Solar Meteorological Data Instrumentation

Solar Tracker, Model ST-1	\$ 820
Eppley Normal Incidence Pyrheliometer, with clear glass, Model 650	980
Eppley Precision Spectral Pyranometer, with clear glass, Model 646	1,090
Dual Channel Printout System, with synchronous tempotec timer, Model 618-3DCP	2,250
Panel Digital Voltmeter	200
Recording Thermograph, Model No. 151-1, Science Associates, Inc.	270
Princeton Wind Set No. 414, Science Associates, Inc.	<u>220</u>
Subtotal	\$ 5,380

Solar Collector

Used for gaining working experience with different types of collectors. Forty square feet each of three different liquid collectors at \$15.00 per square foot	\$ 1,800
Modular Collector Kits (New Jersey Aluminum, \$660.00 each)	1,320
Changeable Absorber Plates for Modular Collectors, copper roll bond, 2 (Kalwall Corp., \$88.00 each)	176
Aluminum Roll Bond, 2 (Kalwall Corp., \$55.00 each)	110
Flat Aluminum for Air Systems, 2 (Kalwall Corp., \$30.00 each)	60
Circulating Pumps, 2 (Kalwall Corp., Teel pump, \$55.00)	110
Air Blower, 2 (Kalwall Corp., Dayton K4CO13, \$28.00)	56
Miscellaneous Materials, including sealant, tubing, ducting, insulation, etc.	250
Flowmeters, 2 (Wallace & Tiernan, Model 5510AO-1-2-06, \$90.00)	180
Various Glazing Materials, including glass and fiberglass	250
Three Focusing Tracking Collector Units, with tracking mechanisms (Northrup, Inc.)	1,100
Six Parabolic Nontracking Focusing Units (White Line Corp., \$110 per unit)	660
Mounting Materials for all Collectors	<u>850</u>
Subtotal	\$6,922

Thermal Storage

Liquid Storage System, including steel and concrete drums, supports and insulation	\$ 450
Air Storage System, including plywood, lumber, insulation rocks, etc.	450
Latent Heat Storage System, including plywood, insulation, heat storage trays, and fused salts	<u>900</u>
Subtotal	\$1,800

Instrumentation Support Equipment Special to Solar Technology

Hot Wire Anemometer [Science Associates, Inc. No. 447(1)-1]	\$ 450
Digital Thermometer with External Thermistor Probe, 5 (Electrometics, \$140 each)	700
Thermistor Sensors, 30 (Electrometics, \$12 each)	360
Thermistor Switch Box (Electrometics)	25
Thermistor Hook-up Wire, 3,000 feet (Radio Shack, \$0.10 per foot)	300
Flowmeters, 3 (Wallace & Tiernan, Model 5510A0-1-2-06, \$93.00)	<u>279</u>
Subtotal	\$2,114

Solar System Simulators

Simulators are extremely useful for teaching principles before the student experiments on the real equipment. This type of simulator is completely interactive, permitting the teacher to familiarize the student with the effect of varying numerous solar parameters. Twenty-four major system malfunctions can be inserted by the teacher to introduce the student to trouble-shooting.

Solar System simulators (Omnidata, Inc. Model 327)	\$ 6,385
Printer Drawer Interface (Omnidata, Inc. PDI-1)	252
Student Tracking Printer (Omnidata, Inc. STP)	<u>875</u>
Subtotal	\$ 7,512

Calculators

Many of the sizing and design calculations are being carried out on small, programmable calculators. There are several companies making available prewritten program cards for solar sizing and design calculations. Calculators of this type are not standard equipment at most colleges.

Programmable Calculator, 2 (Texas Instruments, Model 59, \$253.00)	\$ 506
Printer for Calculator, 2 (Texas Instruments, Model PC-100A, \$176.00)	352
Programmable Calculator with printer, 2 (Hewlett-Packard, Model 97, \$710.00)	<u>1,420</u>
Subtotal	\$ 2,278
Shipping estimate for above items:	<u>2,500</u>
Total Laboratory Costs	\$44,921

In addition, one could spend another \$6,000 on solar refrigeration equipment and \$2,000 on photovoltaic equipment. As well, there will be construction costs incurred for installation of outdoor demonstrations. Navarro College has estimated such costs to be around \$8,500.

APPENDIX H
SCOTT COMMUNITY COLLEGE
SOLAR ENERGETICS TECHNOLOGY
EQUIPMENT LIST

SERIO 

Supplied by Robert N. Illingsworth^a

Item	Qty	Distributor	Cost	
			Unit	Total
Alnor Velometer	1	Dennis Co.		\$453.20
Solar System Trainer AP-3	1	Lennox		2,500.00
ST-17 Solar Heat Service Trainer	1	Lennox		1,500.00
GB-5 Solar Schematic Trainer	1	Lennox		700.00
Solar Panels Complete	1	Solaron		6,347.81
Solar Aire Demo System w/collectors	10	Illowa Solar		6,620.00
Air Control Unit. Storage Package (1500 trays). Installation manual				
FV2 Flo Vu Water Table	1	Lennox		795.00
RT5 Solar Cycle Trainer	1	Lennox		700.00
EB3 Heat-Cool Schematic Electric	1	Lennox		495.00
EB2 Heat-Cool Schematic Oil	1	Lennox		495.00
RT-3 Heat Pump Cycle Trainer	1	Lennox		695.00
EB-4 Heat Pump Schematic Trainer	1	Lennox		750.00
ST-1A Potential Relay Trainer	1	Lennox		360.00
ST-2 Basic Electricity Trainer	3	Lennox	\$350.00	1,050.00
ST-4 Gas Heat Service Trainer	3	Lennox		1,195.00
ST-7 Direct Spark Ignition Trainer	1	Lennox		795.00
ST-9 Heat Pump Service Trainer	1	Lennox		1,295.00
ST-17 Solar Heat Service Trainer	1	Lennox		1,500.00
BT-1 Bi Metal Trainer	1	Lennox		495.00
GT-1 Gas Fundamentals Trainer	1	Lennox		440.00
OT-1 Oil Fundamentals Trainer	1	Lennox		415.00
OT-2 Cad Cell Trainer	3	Lennox	150.00	450.00
OT-3 Oil Burner Trainer	1	Lennox		580.00
OT-4 Oil Pump Trainer	1	Lennox		350.00
MIP-7 Flue and Chimney Trainer	3	Lennox	85.00	255.00
MIP-8 Plastic House Trainer	3	Lennox	165.00	495.00
AP-2 Air Distribution System Trainer	2	Lennox	995.00	1,990.00
AP-5 Hydronic Principles Trainer	1	Lennox		795.00
SHW-2 Domestic Water Heaters(solar)	1	Lennox		1,450.00
LE-8 Solar Test Equipment	1	Lennox		1,880.00
LE-4 Basic Test Equipment	1	Lennox		1,195.00
322 Electric Home Alc.	1	Omnicdata Inc.		3,615.00
STP Student Tracking Printer	2	Omnicdata Inc.	705.	1,410.00
326 Heat Pump Technology	1	Omnicdata Inc.		4,198.00
327 Solar Energy Simulator	1	Omnicdata Inc.		5,833.00
			Total	\$54,092.01

^aSee Appendix A for contact information.

SERIO 

APPENDIX I

**CLASSROOM MATERIALS SAMPLE
COMMUNITY COLLEGE OF DENVER
RED ROCKS CAMPUS
SOLAR ENERGY INSTALLATION & MAINTENANCE PROGRAM**

SERIO 

Supplied by Craig Hilton^a

BIBLIOGRAPHY

COURSE: Basic Solar Systems, Solar System Design and Layout, Solar Panel Arrays

Anderson, B.; Riordan, M. 1976. The Solar Home Book: Heating, Cooling, and Designing with the Sun. Harrisville, NH: Cheshire Books.

COURSE: Domestic Hot Water System, Solar System Maintenance, Solar Panel Installation

Montgomery, Richard 1978. The Solar Decision Book: Your Guide to Making a Sound Investment. Midland, MI: Dow Corning Corp.

Sheet Metal and Air Conditioning Contractors National Association. 1978. Fundamentals of Solar Heating. Vienna, Virginia.

COURSE: Solar Engineering Technology I and II

Winn, B.; Karaki, S.; Lof, G.; et al. 1977a. Solar Heating and Cooling of Residential Buildings: Design of Systems. Ft. Collins, CO: Colorado State University, Solar Energy Applications Laboratory; U.S. GPO; Oct.

———. 1977a. Solar Heating and Cooling of Residential Buildings: Sizing, Installation and Operation of Systems. Ft. Collins, CO: Colorado State University, Solar Energy Applications Laboratory; U.S. GPO; Oct.

International Telephone and Telegraph Corp. 1977. Solar Heating Systems Design Manual. Morton Grove, IL: Training & Education Dept. Fluid Handling Division.

U.S. Dept. of Housing and Urban Development. 1977. Intermediate Minimum Property Standards for Solar Heating and Domestic Hot Water System. U.S. Government Printing Office.

COURSE: Basic Solar Controls, Advance Solar Controls.

Miles, V.C. 1965. Thermostatic Control Principles and Practice. London, England: Butterworth & Co., 88 Kingways.

Farber, Joseph. 1978. Control and Pumps for Solar Heating and Cooling. Newark, DE: Publishing Office of the American Section of the International Solar Energy Society; Dec.

^aSee Appendix A for contact information.

COURSE: Passive Solar System

Mazria, Edward. 1979. The Passive Solar Energy Book. Emmaus, PA: Rodale Press.

Prowler, Don, ed. 1978. Proceedings of the 1978 Passive Solar Conference, Philadelphia, PA., March 1978. Philadelphia, PA. Mid-Atlantic Solar Energy Assn.

Cook, Jeffrey. Passive Systems '78, Newark, DE: Publishing Office of the American Section of the International Solar Energy Society; Oct. 1976.

Stromberg, R.P.; Woodall, S.O. 1977. Passive Solar Buildings: A Compilation of Data and Results. Springfield, VA: National Technical Information Service; August.

Kroner, Walter; Haviland, David. 1978. Passive Design Ideas for the Energy Conscious Builder. Rockville, MD: A National Solar Heating and Cooling Information Center Publication.

Students are provided with handout materials in each class. Memberships in the International Solar Energy Society and the Colorado Solar Energy Association are encouraged together with subscriptions to such magazines as Solar Age, Solar Engineering, and Solar Heating & Cooling.

Code Information Used in Classroom:

International Association of Plumbing and Mechanical Officials. 1976. Uniform Solar Energy Code, 1976 Edition. Los Angeles, CA; Sept.

International Association of Plumbing and Mechanical Officials. 1977. Uniform Plumbing Code, 1976 Edition. Los Angeles, CA; Jan.

Sheet Metal and Air Conditioning Contractors National Association. 1978. Installation Standards for One and Two Family Dwellings and Multifamily Housing Including Solar. Vienna, VA; Jan.

State of Colorado, Office of State Planning and Budgeting and the Department of Local Affairs. 1977. State of Colorado Energy Conservation Standards. Denver, CO: Colorado Division of Housing; Nov.